

Experimental test results of an automatic voltage regulator with independent phase voltage controllers

Wojciech Śleszyński¹, Artur Cichowski², Krzysztof Jakub Szwarz², Robert Małkowski²,
Paweł Szczepankowski², Andrzej Augusiak², Dariusz Karkosiński^{2*}, Ryszard Strzelecki²

¹Arex Sp. Z.o.o.

²Gdańsk University of Technology

Abstract. The growing number of distributed renewable energy sources and dynamic constant-power loads (e.g. electric vehicle charging stations) pose new challenges for network operators. These changes result in alterations to network load profiles and load flows, leading to greater voltage volatility. One effective solution to these problems can be the use of automatic voltage regulators (AVRs), which stabilize and symmetrize voltage output, whether at distribution transformers (DTs) or elsewhere in the distribution network. The device developed by the authors consists of two bidirectional power converters and three single-phase transformers connected in series to the low-voltage grid as a stabilizer. The proposed control system provides accurate and fast regulation of the AVR's output voltage (within the range of $\pm 10\%$ of the nominal grid voltage), with each phase being independently adjusted, regardless of the type of power load. The article includes test results demonstrating selected functionalities of the developed AVR. The physical model of the device discussed in the article is a research component of the LINTE² laboratory of the Gdańsk University of Technology.

Key words: automatic voltage regulator, grid voltage control, distribution transformer, hybrid transformer, power electronics converter, smart grids

1. INTRODUCTION

The operating conditions of the power distribution grid have changed in recent years. The number of loads with constant power demand has increased [1, 2]. For such electrical equipment, a decrease in the supply voltage causes an increase in current consumption, exacerbating voltage drop in the power line. On the other hand, the growing number of renewable generation systems connected to distribution grids can cause problems with excessively high voltage in the power grid. Additionally, renewable energy is characterized by high variability of energy generation depending on weather conditions [3, 4]. As a result, the power flow in distribution grids becomes more complicated, making it more difficult to maintain supply voltage within acceptable limits [5, 6].

A common method of maintaining an appropriate voltage level in the distribution grid is through on-load tap changing of the transformers [6]. This is typically achieved using electromechanical tap changers, which have drawbacks such as poor dynamics, arcing and high operation costs [7, 8, 9]. Thyristor tap changers can improve the dynamic of voltage control, but at the cost of additional conduction losses and the output voltage can still be changed discretely [5, 9].

Smooth and fast regulation of voltage and current in the distribution network is enabled by power electronics transformers (or solid-state transformers (SST)) [10, 11, 12]. However, their significantly higher price and lower reliability mean that they have not been widely used in distribution networks [8, 13].

In recent years, alongside SST, various types of power electronic systems have been developed to compensate and im-

prove voltage quality in AC transmission networks (Flexible AC Transmission Systems (FACTS)) and distribution grids (Custom Power Devices (CPD)) [14]. The AVR presented in the article is the most similar in terms of topology and functional features to the Unified Power Flow Controller (UPFC) [14, 15, 16], Unified Power Quality Conditioner (UPQC) [17, 18, 19], and particularly the Hybrid Distribution Transformer (HDT) [5, 7, 8, 20, 21, 22].

The UPFC can independently control voltage, phase angle and impedance in the transmission line. This tasks are usually carried out in the fundamental harmonic domain [14]. The UPQC is used in the distribution grid mainly to provide sinusoidal balanced voltage to the load and simultaneously to ensure the flow of sinusoidal and symmetrical currents from the source, irrespective of distortion or unbalance on the load or source side [17].

The power electronic system of HDT combines the functionalities of the aforementioned devices, with characteristic features including close integration with DT and low rated power, typically between 10% and 20% of the distribution transformer. Therefore, the losses of the converter slightly deteriorate the HDT efficiency [5, 7, 8].

This paper presents an automatic voltage regulator based on a back-to-back converter system and a series transformers. It was designed to symmetrize and regulate voltages in distribution network feeding station, but it is feasible to install it at any point in the distribution grid, e.g. at sensitive loads or at places of line cross-section change.

The literature describes many different control methods for systems such as AVR; a brief overview is contained in [17]. The two most common control techniques are the instant-

*e-mail: dariusz.karkosinski@pg.edu.pl

neous active and reactive power method and the synchronous reference frame method. The latter was used to control the AC/DC converter. The DC/AC converter control system consists of three independent phase voltage controllers with the amplitude limitation function and suppression of series transformers saturation, which are the original authors' proposition.

The industrial partner's market analysis shows that there is a demand for two variants of AVR:

- Basic, allowing symmetrization and regulation of output voltages within $\pm 10\%$ of the nominal grid voltage.
- Configurable, realizing the functions of the basic version and additionally: compensation of distortions of output voltages and input currents of AVR, symmetrization of input currents or reactive power compensation. The second version is usually connected with additional AVR upgrade and increased costs of the device as well as longer implementation time.

The results of the conducted research, which are presented in the paper, are for the basic version of AVR.

The novelty of the paper is the output voltage controller for the AVR system. It provides several functionalities that address the following issues:

- 1) Regulation of output voltages - the output voltages of the AVR system are regulated quickly, accurately and independently in each phase. If the reference phase voltages are symmetrical, the AVR naturally balances the output voltages (both magnitude and phase of the fundamental harmonic). The adjustment range is limited by the parameters of single-phase series transformers.
- 2) Limiting of the sinusoidal series voltages without distortions - the algorithm is based on the estimation of the AVR input voltage amplitudes by recursive discrete Fourier transform.
- 3) Resonance suppression of LC output filters - active damping with VSI output currents feedback is used.
- 4) Preventing core saturation of series transformers during normal operation - the controller algorithm adjust the DC components of the VSI output currents.

Although the implemented controller functionalities are well known, their synthesis is the novelty of the paper.

Moreover, the extensive laboratory tests of the AVR system are described. They present the performance of the proposed AVR under various operational scenarios and can provide a reference for designing and optimizing of other control algorithms of AVRs.

2. CHARACTERISTICS OF A PROPOSED AVR LABORATORY MODEL

An illustrative diagram of a laboratory model of a AVR is shown in Figure 1 and the laboratory model is presented in Figure 2.

The AVR was implemented as a combination of two bidirectional converters AC/DC and DC/AC with a common DC-link circuit containing a C_{dc} capacitor. The DC/AC converter consists of three single-phase voltage inverters coupled through LC filters with primary windings of single phase transformers Tr_{SE} . Their secondary windings are connected in series with




Fig. 1. Simplified diagram of the automatic voltage regulator.

Table 1. Basic parameters of a distribution transformer and automatic voltage regulator.

Description	Value
Nominal phase voltage of power grid (U_n)	230.94 V
Nominal frequency of power grid (f_n)	50 Hz
Voltage regulation range of AVR	$\pm 10\% U_n$
Apparent power of the distribution transformer Tr_S (S_{Sn})	50 kVA
Phase-to-phase voltage of primary side of transformer Tr_S (U_{S1n})	400 V
Phase-to-phase voltage of secondary side of transformer Tr_S (U_{S2n})	400 V
Nominal current of DT (I_n)	72.2 A
Apparent power of series transformer Tr_{SE} (S_{SEn})	2 kVA
Phase voltage of primary side of transformer Tr_{SE} (U_{SE1n})	230 V
Phase voltage of secondary side of transformer Tr_{SE} (U_{SE2n})	23 V
Series transformer Tr_{SE} ratio (N_{SE})	10
DC link voltage (U_{dc})	700 V
DC link capacitance (C_{dc})	2 mF
Inductance of LCL filter (L_1)	6 mH
Inductance of LCL filter (L_2)	3 mH
Capacitance of LCL filter (C_1)	2 μ F
Inductance of LC filter (L_f)	8.5 mH
Capacitance of LC filter (C_f)	2.2 μ F

the power lines. The DC/AC converter is powered by a three-phase inverter connected via an LCL filter to the low-voltage side of the distribution transformer. Table 1 summarizes the basic parameters of the AVR and supply system components.

The control algorithm has been implemented in the AVR controller, built on the basis of the TMS320C6672 signal processor and the Cyclone V field-programmable gate array. To execute the control algorithm, the following signals are measured: phase voltages at the input ($u_{Sx}, x \in \{a, b, c\}$) and output (u_{Lx}) of the AVR, the input currents of the grid converter (i_{1x}), the phase currents of the single-phase inverters (i_{fx}) and DC-link voltage (u_{dc}). To protect the AVR against the effects of external short-circuits, the load currents (i_{Lx}) are measured and also incorporated into the control algorithm. To enable protection and disconnection of the AVR from the grid side, two types of bypass circuits were utilized. The shunt system

Experimental test results of an automatic voltage regulator with independent phase voltage controllers




Fig. 2. Laboratory model of the automatic voltage regulator: a) AC/DC/AC converter b) AVR controller c) converters passive filters d) electrical switching devices e) series transformers.

(K_e) was constructed using bidirectional thyristor switches to safeguard the AVR against excessive currents in the converter circuits, such as during external short circuits at the AVR output. The shunt circuit (K_m), based on electromechanical contactors, facilitates the shutdown of the AVR, for example, during failure or AVR maintenance work.

3. CONTROL SYSTEM OF AUTOMATIC VOLTAGE REGULATOR

The AVR control system can be divided into two parts: the control system of the AC/DC converter, which provides a DC voltage of the required value, and the DC/AC inverters that are powered by it. On the other hand, the main task of the DC/AC converter control system is to regulate the phase voltages (fundamental harmonic) at the AVR output within $\pm 10\%$ of the nominal grid voltage.

A. AC/DC converter control system

A classical cascade control system shown in Figure 3 has been implemented in order to control the DC-link voltage. The DC voltage PI controller settings (K_{Pdc} , K_{Idc}) were determined for the 60 Hz control band. The grid currents are regulated in the dq coordinate system rotating synchronously with the angular frequency of the supply voltage. The parameters of the PI con-




Fig. 3. Block diagram of the AC/DC converter control system.

trollers (K_{Pdq} , K_{Idq}) were calculated for a control bandwidth of 320 Hz.

The Cascaded Delayed Signal Cancellation - Phase Locked Loop (CDSC-PLL) algorithm [23] was used to determine the phase angle of the fundamental harmonic of the grid voltage. The PI controller settings used in this algorithm were selected for the 50 Hz control band.

B. DC/AC converter control system

The DC/AC converter allows the generation of appropriate series voltages, which are added to the secondary side voltages of the distribution transformer Tr_S through the transformers Tr_{SE} . Three independent series voltage regulators were proposed, one for each phase. They allow independent and fast adjustment of individual phase voltages on the AVR output. The block diagram of the load voltage controller for one phase is shown in Figure 4.

Using the recursive discrete Fourier transform (RDFT) algorithm, the amplitude of the fundamental harmonic (U_{S1x}) of the input phase voltage (u_{Sx}) is calculated and subtracted from the amplitude of the reference load voltage (U_{Lref}). In this way, the amplitude of the series voltage (U_{SEx}) to be obtained at the secondary side of the transformer Tr_{SE} is calculated. This amplitude is limited to the maximum value that can be generated (U_{SEmax}). The value of U_{SEmax} is determined by the parameters of the series transformer used, the value was assumed to be equal to the amplitude of the rated voltage of the secondary side of the transformer Tr_{SE} . Similarly, the amplitude (U_{Lrefx}) of the reference phase voltage at the AVR output (u_{Lrefx}) is equal to U_{Lref} if it is less than the maximum achievable voltage, otherwise it is limited to $U_{Lrefx,min} = U_{S1x} - U_{SEmax}$ or $U_{Lrefx,max} = U_{S1x} + U_{SEmax}$.

The reference values u_{SErefx} and u_{Lrefx} are cosine signals, scaled by the Tr_{SE} transformer ratio N_{SE} , whose argument is equal to the sum of the instantaneous phase Θ_s of the supply voltage, estimated by the CDSC-PLL algorithm and a fixed phase shift ($\phi_a = 0, \phi_b = -2\pi/3, \phi_c = 2\pi/3$). The voltage u_{SErefx} is one of the components of the reference output voltage (u_{fx}) of the voltage source inverter. Its value depends directly on the difference between the referenced and estimated amplitude of the input phase voltage.

The difference of u_{Lrefx} and the measured load voltage u_{Lx} , is the voltage regulation error e_{ux} , which is fed to the input of a resonant controller (R_{res}) with transfer function:

$$R_{res}(z) = K_{IL} \frac{\sin(\omega_1 T_s)}{2\omega_1} \frac{1 - z^{-2}}{1 - 2\cos(\omega_1 T_s)z^{-1} + z} \quad (1)$$

where: ω_1 is the mains angular frequency and K_{IL} - integral




Fig. 4. Block diagram of the load voltage controller for one phase of the DC/AC converter.

gain of the resonant controller. The main task of the resonant regulator is to eliminate the static error of the load voltage. Among other things, it corrects a voltage error related to voltage drops on the series impedances of the series transformer and L_f choke. The output signal of the resonant regulator is the second component of the reference output voltage u_{fx} .

In the presented control system, negative feedback from the inverter output current (i_{fx}) was used to actively suppress the resonance of LC circuit. This coupling also limits the current i_f due to saturation of the series transformer during the transient state. The gain of the proportional controller was calculated from the formula:

$$K_{Pf} = \sqrt{2L_f/C_f} - R_f \quad (2)$$

Since the load current is measured for AVR protection and diagnostics, this signal was also used in the control system (taking into account the series transformer ratio). The difference of these currents, after amplification, is another component of u_{fx} .

The last component of this voltage is the output signal of the integral term processing the current i_{fx} , this term was used to eliminate the constant component from the primary current of series transformer and thus to reduce the residual magnetization of the series transformer core (the problem occurs in transients).

The inverter's reference output voltage u_{fx} , limited to the allowable maximum value U_{fmax} , is the input signal of the pulse width modulation algorithm that defines the turn-on signals of individual inverter transistors.

The integral gains K_{IL} and K_{If} were selected by simulation and experimental studies. A summary of the parameters of the AC/DC and DC/AC converter control systems is given in Table 2.

4. LABORATORY RESULTS

A. Case 1 - variation of the reference value of load voltages

The tested system was supplied from the medium voltage grid of Gdańsk University of Technology (GUT) through a step-down transformer T1. The topology of the test system is presented in Figure 5.

Table 2. Basic parameters of a distribution transformer and automatic voltage regulator. [!h]

Description	Value
Proportional gain of DC-link voltage controller (K_{Pdc})	1.12 A / V
Integral gain of DC-link voltage controller (K_{Idc})	68.74 A / Vs
Proportional gain of current controller of AC/DC converter (K_{Pdq})	14.25 V / A
Integral gain of current controller of AC/DC converter (K_{Idq})	3.55 V / As
Integral gain of resonant controller of HDT output voltage (K_{IL})	200 V / Vs
The frequency of the resonant controller of HDT output voltage (ω_1)	100π rad / s
Proportional gain of i_{fx} current controller (K_{Pf})	88.32 V / A
Integral gain of i_{fx} current controller (K_{If})	10 V / As
Maximum value of the series voltage amplitude (U_{SEmax})	32.66 V
Maximum value of the inverter phase voltage (U_{fmax})	380 V
Sampling period (T_s)	50 μs




Fig. 5. Test system topology - case 1.

In order to assess the quality of operation of the AVR control system, including the algorithm of limiting the amplitudes of additive series voltages, laboratory tests were carried out at various reference values of load voltage and different types of load:

- symmetrical three-phase resistor (Figure 6)
- three-phase resistor and a six-pulse rectifier connected in parallel (Figure 7)
- single-phase resistor (Figure 8).

Figures 6-8 show the RMS waveforms of selected signals in the AVR system when the load voltage set points (U_{Lref}) are varied in the following sequence: $1.0U_n$, $1.05U_n$, $0.95U_n$,

Experimental test results of an automatic voltage regulator with independent phase voltage controllers

1.08 U_n , 0.92 U_n , 1.1 U_n , 0.9 U_n , 1.15 U_n , 0.85 U_n , 1.0 U_n . In Figures 6-8, the signals in phases a, b, c are marked with red, green and blue, respectively, and the reference output voltage U_{Lref} - in magenta.

The RMS values presented in the figures were calculated in a moving window of fixed length (N), based on the general formula:

$$X[k] = \sqrt{\frac{1}{N} \sum_{n=k-N+1}^k x^2[n]}, N = f_s/f_n \quad (3)$$

where: x is a signal registered by the AVR controller and f_s - sampling frequency. The RMS values of the series voltages (U_{SEx}) have been calculated as the differences between the RMS values of the output and input voltages of the AVR ($U_{SEx} = U_{Lx} - U_{Sx}$).

Figures 6f-8f show the RMS waveforms of load currents (I_{Lx}) that contain information about the value and symmetry of the load connected to the AVR output.

In the case shown in Figure 6, the AVR was loaded with a three-phase symmetrical resistor providing currents of approximately 1.05 I_n (Figure 6f) at the rated output voltage.

Figure 7 shows a test in which the AVR was loaded with a symmetrical resistive load of about 0.26 S_n and a three-phase six-pulse diode rectifier loaded with resistance, the rectifier was connected to the AVR output through chokes of an inductance of 3 mH. The total apparent power of the load was 0.77 S_n .

Figure 8 concerns the AVR operation with an unbalanced single-phase resistive load in phase c . The RMS value of the current in the loaded phase is about 0.8 I_n (Figure 8f) at the rated output voltage.

Figures 6a-8a show the RMS waveforms of the referenced and measured phase voltages at the AVR output. For the first two types of loads (Figures 6a-7a), the setpoints 1.08 U_n , 1.1 U_n , 1.15 U_n and 0.85 U_n have not been reached due to the applied limitation of the series voltages U_{SEx} to $\pm 0.1U_n$ (cf. Figures 6d-7d). For the other setpoints, the differences in the RMS values of the referenced and measured voltages are within the tolerance band of $\pm 0.2\%U_n$ (Figures 6b-7b). Since the reference voltage is the same for each phase, thus the output voltages are balanced. The spiky behavior of the signals presented in Figures 6b-8b is a result of transients related to step changes in the reference voltage and the limited dynamics of the AVR control system. Due to the very high magnification of the waveforms near zero, the vanishing transients are visible for a long time. Additionally, because of the relatively small range of the y-axis, $U_{Lref} - U_{Lx}$ differences outside this range are not visible in a few of the time intervals in Figures 6b-8b.

The situation for the single-phase load (Figures 8a,b) is slightly different than for the previously discussed cases. In the unloaded phases (a and b) the RMS values of load voltages do not reach the setpoint values when U_{Lref} is equal to 0.9 U_n , 1.15 U_n , 0.85 U_n (Figures 8a,b), while in the phase c - when U_{Lref} is equal to 1.1 U_n , 1.15 U_n , 0.85 U_n . In case of $U_{Lref} = 1.08U_n$, the maximum series voltage is generated in phase c (Figure 8d). Despite this, the output voltage is not




Fig. 6. RMS waveforms during the step changes of the load voltages with three-phase symmetrical resistive load.




Fig. 7. RMS waveforms during the step changes of the load voltages with three-phase symmetrical nonlinear load.




Fig. 8. RMS waveforms during the step changes of the load voltages with single-phase unsymmetrical resistive load.

able to reach the referenced value and a small error (approx. $0.1\%U_n$) is clearly visible within the assumed tolerance band of $\pm 0.2\%U_n$.

A slight unbalance, visible in the AVR input voltages for all types of loads (Figures 6c-8c), is not present in the AVR output voltages (Figures 6a,b-8a,b), when the additive series voltages are not limited. If the series voltage is limited in at least one phase, the AVR output voltages may be unbalanced. In such a situation, the voltages in the other two phases are not regulated in order to balance the AVR output voltages. This is due to the fully independent operation of the voltage controller in each phase. The described operating state of the AVR system can be seen clearly in Figure 8 when $U_{Lref} = 1.1U_n$ (period: 1.25 - 1.5s). Additive series voltage in phase *c* is limited while in the other phases are still below the limit (Fig. 8d). Consequently, the output voltages in phases *a* and *b* reach the referenced values, while the voltage in phase *c* is noticeably lower. An analogous situation is apparent when $U_{Lref} = 0.9U_n$ (period: 1.5s - 1.75s), where only the output voltage in phase *c* reaches the reference value and the voltages in the other phases are higher than it due to limitations.

Load voltage control error e_{ux} is the difference between a reference voltage u_{Lrefx} and a measured voltage u_{Lx} at the AVR output phase, where u_{Lrefx} is the reference value after passing through the amplitude limiting algorithm. Therefore the RMS value of the load voltage control error (Figures 6e-8e) is a measure of the imperfection between referenced and measured voltage at the AVR output. In a situation where the fundamental harmonics of the output voltages are generated pre-




Fig. 9. Amplitude spectra of selected signals at $U_{Lref} = 1.15U_n$ and three-phase symmetrical non-linear load.




Fig. 10. Test system topology - case 2.

cisely (as in our case, cf. Fig 9d), the E_{ux} signals indirectly characterize the level of distortion of the load voltages. It is significantly higher for a nonlinear load (Figure 7e), despite its lowest power.

Similar conclusions about the operation of the system can be obtained by analyzing the spectra of the signals presented in Figures 6-8. For example, Figure 9 shows amplitude spectra of u_{Lx} , u_{Sx} , u_{SEx} , control errors e_{ux} , and currents i_{Lx} for a nonlinear load at $U_{Lref} = 1.15U_n$ (cf. Figure 7).

The fundamental harmonics in the spectra of load voltage control errors E_{hux} (Figure 9d) reach values below $0.1U_n$, which proves that the resonant controller R_{rez} precisely regulates the value of the fundamental harmonic in steady state. However, due to the relatively narrow frequency band, it does not allow to reduce the higher harmonics of the load voltages. Nevertheless, with precise regulation of the fundamental harmonics of the load voltages and its relatively small distortions, the RMS values are also stabilized with high accuracy. The content of higher harmonics in the AVR output (Figure 9a) and input voltages (Figure 9b) is very similar. The load voltage control system does not significantly modify the voltage spectrum of the distribution transformer, the additive series voltages (Figure 9c) are approximately sinusoidal.

B. Case 2 - variation of the AVR input voltages

The tests were carried out in the arrangement shown in Figure 10.

The AVR input voltages are varied by changing the taps of

Experimental test results of an automatic voltage regulator with independent phase voltage controllers




Fig. 11. RMS waveforms during the changes in AVR input voltages while transferring energy to the mains.




Fig. 12. RMS waveforms during the changes in AVR input voltages while constant power load with $Q_L/P_L = 0.4$

transformer T2. This transformer is equipped with a thyristor on-load tap changer. In this case, a bidirectional AC/DC/AC converter was connected to the AVR output, which allowed:

- transfer of energy to the power grid in constant current mode with power factor (PF) close to -1 (Figure 11)
- energy consumption in constant power mode with $Q_L/P_L = 0.4$ (Figure 12).

In both cases the AVR operates with a load close to its rated capacity, the RMS current waveforms are shown in Figures 11e, 12e and the waveforms of the active and reactive power - in Figures 11d and 12d. Changes of supply voltages are shown in Figures 11a, 12a. In either case, AVR correctly maintains the reference output voltage (Figs 11c, 12c) until the additive series voltages are within $\pm 0.1U_n$ (Figs 11b, 12b). When the differences between output and input voltages exceed the regulating capacity of the AVR, it generates its maximum additive voltage. The obtained results encourage the authors to develop an algorithm enabling the implementation of the physical model of Distribution Transformer with Multi-Zone Voltage Regulation described in paper [24]. The obtained results will be presented in subsequent publications.

C. Case 3 - transient states

The chapter presents selected transients related to:

- changes in the reference value of the load voltage (Figures 13 and 14)
- switching on and off different types of loads (Figures 15-19).

Figures 13 and 14 show the selected transients associated with step changes in load voltages, whose RMS waveforms are shown in Figures 6a and 7a, respectively, the time axis is the same in the corresponding figures. In both cases, the additive series voltages with maximum amplitude must change phase by 180 degrees. Despite the largest possible setpoint changes, the control system reduces the errors almost completely during one period of the mains voltage.

Figure 15 shows the transient state caused by switching on, at nominal AVR output voltage, a three-phase resistive load with a power slightly above rated. Figure 16 shows, at nominal load voltage, the switching on of a symmetrical inductive load of about $0.8S_n$. The control system ensures stable operation of the AVR and reduces the voltage error significantly during one period of the supply voltage.

Figure 17 illustrates the operation of a three-phase load in the form of the three-phase resistor (ca. $0.26S_n$) and a six-pulse diode rectifier with an output resistance (ca. $0.75S_n$) at a load voltage of $1.05U_n$. At time $t = 36ms$, phase *b* of the rectifier supply was disconnected causing a load asymmetry. The change in the value and type of the load causes a slight tran-




Fig. 13. Step change of the reference load voltage from $1.15U_n$ to $0.85U_n$ under symmetrical three-phase resistive load




Fig. 14. Step change of the reference load voltage from $0.9U_n$ to $1.15U_n$ under unsymmetrical single-phase resistive load

sient, the output voltage adjustment time is about one period of the mains voltage.

Figures 18 and 19 show the transients related to the soft loading of the AVR output using the power electronic converter systems. Figure 18 presents the termination of energy transfer to the distribution grid and Figure 19 - the beginning of capacitive reactive power generation. In case of gradual change in load on the AVR output the voltage control errors are almost unchanged.

5. CONCLUSIONS

Experimental tests have confirmed correct operation of the AVR for resistive, inductive, capacitive, constant-current, constant-power, nonlinear and asymmetrical loads, as well as in cooperation with generating units transmitting energy to the mains. The AVR described in this paper exhibits appropriate dynamics. The control system significantly reduces the voltage error during half of the period of the supply voltage, regardless of the type of load. The error of the output voltage regulation in the steady state does not exceed 0.2% of U_n . The accuracy of the control is independent of the type of disturbance—whether it's a load change or a generation change. Further development of the AVR is planned in the near future, particularly the imple-




Fig. 15. Switching on a symmetrical three-phase resistive load of about $1.05S_n$ at $U_{Lref} = 1.0U_n$




Fig. 16. Switching on a symmetrical three-phase inductive load of about $0.85S_n$ at $U_{Lref} = 1.0U_n$




Fig. 17. Disconnection of phase b of the power supply of the six-pulse diode rectifier (ca. $0.75U_n$) during operation of the symmetrical three-phase resistor (ca. $0.26U_n$), $U_{Lref} = 1.05U_n$.

Experimental test results of an automatic voltage regulator with independent phase voltage controllers




Fig. 18. Switching off the power electronic converter system transmitting energy to the supply network.




Fig. 19. Switching on the power electronic converter system generating the capacitive reactive power.

mentation of control that will provide compensation for higher harmonics of the output voltage and input current of the AVR, as well as the capability of reactive power compensation.

Research is planned using the AVR as part of a smart grid, which will be supported by the IEC61850 communication protocol implemented in the device.

REFERENCES

- [1] A. G. Anastasiadis, G. P. Kondylis, A. Polyzakis, and G. Vokas, "Effects of increased electric vehicles into a distribution network," *Energy Procedia*, vol. 157, pp. 586–593, 2019, technologies and Materials for Renewable Energy, Environment and Sustainability (TM-REES). [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S1876610218311925>
- [2] V. Boglou, C.-S. Karavas, K. Arvanitis, and A. Karlis, "A fuzzy energy management strategy for the coordination of electric vehicle charging in low voltage distribution grids," *Energies*, vol. 13, no. 14, 2020. [Online]. Available: <https://www.mdpi.com/1996-1073/13/14/3709>
- [3] J. Hu, Z. Li, J. Zhu, and J. M. Guerrero, "Voltage stabilization: A critical step toward high photovoltaic penetration," *IEEE Industrial Electronics Magazine*, vol. 13, no. 2, pp. 17–30, 2019.
- [4] T. S. Ustun, J. Hashimoto, and K. Otani, "Impact of smart inverters on feeder hosting capacity of distribution networks," *IEEE Access*, vol. 7, pp. 163 526–163 536, 2019.
- [5] A. Carreno, M. Perez, C. Baier, A. Huang, S. Rajendran, and M. Malinowski, "Configurations, power topologies and applications of hybrid distribution transformers," *Energies*, vol. 14, no. 5, 2021. [Online]. Available: <https://www.mdpi.com/1996-1073/14/5/1215>
- [6] R. Małkowski, M. Izdebski, and P. Miller, "Adaptive algorithm of a tap-changer controller of the power transformer supplying the radial network reducing the risk of voltage collapse," *Energies*, vol. 13, no. 20, 2020. [Online]. Available: <https://www.mdpi.com/1996-1073/13/20/5403>
- [7] J. Burkard and J. Biela, "Hybrid transformers for power quality enhancements in distribution grids - comparison to alternative concepts," in *NEIS 2018; Conference on Sustainable Energy Supply and Energy Storage Systems*, 2018, pp. 1–6.
- [8] J. Burkard and J. Biela, "Evaluation of topologies and optimal design of a hybrid distribution transformer," in *2015 17th European Conference on Power Electronics and Applications (EPE'15 ECCE-Europe)*, 2015, pp. 1–10.
- [9] J. de Oliveira Quevedo, F. E. Cazakevicius, R. C. Beltrame, T. B. Marchesan, L. Michels, C. Rech, and L. Schuch, "Analysis and design of an electronic on-load tap changer distribution transformer for automatic voltage regulation," *IEEE Transactions on Industrial Electronics*, vol. 64, no. 1, pp. 883–894, 2017.
- [10] J. E. Huber and J. W. Kolar, "Solid-state transformers: On the origins and evolution of key concepts," *IEEE Industrial Electronics Magazine*, vol. 10, no. 3, pp. 19–28, 2016.
- [11] H. Açıkgöz, O. F. Keçecioglu, A. Gani, C. Yıldız, and M. Şekkeli, "Optimal control and analysis of three phase electronic power transformers," *Procedia - Social and Behavioral Sciences*, vol. 195, pp. 2412–2420, 2015, world Conference on Technology, Innovation and Entrepreneurship. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S1877042815037192>
- [12] Y. Miao, "Research on power electronic transformer applied in AC/DC hybrid distribution networks," *Global Energy Interconnection*, vol. 1, no. 3, p. 8, 2018.
- [13] J. E. Huber and J. W. Kolar, "Applicability of solid-state transformers in today's and future distribution grids," *IEEE Transactions on Smart Grid*, vol. 10, no. 1, pp. 317–326, 2019, conference Name: IEEE Transactions on Smart Grid.
- [14] R. M. Strzelecki, *Power Electronics in Smart Electrical Energy Networks*. Springer Science & Business Media, 2008, google-Books-ID: LqWPPiSM5M0C.
- [15] M. M. Haque, M. S. Ali, P. Wolfs, and F. Blaabjerg, "A UPFC for voltage regulation in LV distribution feeders with a DC-link ripple voltage suppression technique,"

- IEEE Transactions on Industry Applications*, vol. 56, no. 6, pp. 6857–6870, 2020, conference Name: IEEE Transactions on Industry Applications.
- [16] A. Lashkar Ara, A. Kazemi, and S. Nabavi Nikaki, “Modelling of optimal unified power flow controller (oupf) for optimal steady-state performance of power systems,” *Energy Conversion and Management*, vol. 52, no. 2, pp. 1325–1333, 2011. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S0196890410004322>
- [17] V. Khadkikar, “Enhancing electric power quality using UPQC: A comprehensive overview,” *IEEE Transactions on Power Electronics*, vol. 27, no. 5, pp. 2284–2297, 2012, conference Name: IEEE Transactions on Power Electronics.
- [18] X. Zhao, X. Chai, X. Guo, A. Waseem, X. Wang, and C. Zhang, “Impedance matching-based power flow analysis for UPQC in three-phase four-wire systems,” *Energies*, vol. 14, no. 9, p. 2702, 2021, number: 9 Publisher: Multidisciplinary Digital Publishing Institute. [Online]. Available: <https://www.mdpi.com/1996-1073/14/9/2702> (Accessed 2021-12-10).
- [19] M. Hosseini, H. Shayanfar, and M. Fotuhi-Firuzabad, “Modeling of unified power quality conditioner (UPQC) in distribution systems load flow,” *Energy Conversion and Management*, vol. 50, no. 6, pp. 1578–1585, Jun. 2009. [Online]. Available: <https://linkinghub.elsevier.com/retrieve/pii/S0196890409000594> (Accessed 2022-01-03).
- [20] S. Bala, D. Das, E. Aeloiza, A. Maitra, and S. Rajagopalan, “Hybrid distribution transformer: Concept development and field demonstration,” in *2012 IEEE Energy Conversion Congress and Exposition (ECCE)*, 2012, pp. 4061–4068, ISSN: 2329-3748.
- [21] P. Costa, G. Paraíso, S. F. Pinto, and J. F. Silva, “A four-leg matrix converter based hybrid distribution transformer for smart and resilient grids,” *Electric Power Systems Research*, vol. 203, p. 107650, 2022. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S0378779621006313>
- [22] M. Díaz-Ojeda, J. Rodríguez-Rodríguez, J. Hernández-Sánchez, F. Trillaud, J. Olivares-Galván, and R. Escarela-Pérez, “Cross phases hybrid transformer for managing and improving the energy quality,” *International Journal of Electrical Power & Energy Systems*, vol. 131, p. 107005, Oct. 2021. [Online]. Available: <https://linkinghub.elsevier.com/retrieve/pii/S0142061521002453> (Accessed 2022-01-03).
- [23] A. Cichowski, W. Śleszyński, J. Nieznanski, and P. Szczepankowski, “Compensation of dead time effects for shunt active power filters,” in *2015 IEEE International Conference on Industrial Technology (ICIT)*, 2015, pp. 2241–2247.
- [24] R. Strzelecki, W. Matelski, R. Małkowski, V. Tomasov, L. Wolski, and A. Krahel, “Distribution transformer with multi-zone voltage regulation for smart grid system application,” in *2019 IEEE 6th International Conference on Energy Smart Systems (ESS)*, 2019, pp. 132–137.