

Article

# Innovative Turbine Intake Air Cooling Systems and Their Rational Designing

Andrii Radchenko <sup>1</sup>, Eugeny Trushliakov <sup>1</sup>, Krzysztof Kosowski <sup>2</sup>, Dariusz Mikielwicz <sup>2,\*</sup> and Mykola Radchenko <sup>1</sup>

<sup>1</sup> Department of Ship Electroenergetic Systems, Admiral Makarov National University of Shipbuilding, Heroes of Ukraine Avenue 9, 54000 Mykolayiv, Ukraine; andrad1978@gmail.com (A.R.); rektor@nuos.edu.ua (E.T.); nirad50@gmail.com (M.R.)

<sup>2</sup> Faculty of Mechanical Engineering, Gdańsk University of Technology, 80-233 Gdańsk, Poland; krzysztof.kosowski@pg.edu.pl

\* Correspondence: [dariusz.mikielwicz@pg.edu.pl](mailto:dariusz.mikielwicz@pg.edu.pl)

Received: 15 September 2020; Accepted: 20 November 2020; Published: 25 November 2020



**Abstract:** The efficiency of cooling ambient air at the inlet of gas turbines in temperate climatic conditions was analyzed and reserves for its enhancing through deep cooling were revealed. A method of logical analysis of the actual operation efficiency of turbine intake air cooling systems in real varying environment, supplemented by the simplest numerical simulation was used to synthesize new solutions. As a result, a novel trend in engine intake air cooling to 7 or 10 °C in temperate climatic conditions by two-stage cooling in chillers of combined type, providing an annual fuel saving of practically 50%, surpasses its value gained due to traditional air cooling to about 15 °C in absorption lithium-bromide chiller of a simple cycle, and is proposed. On analyzing the actual efficiency of turbine intake air cooling system, the current changes in thermal loads on the system in response to varying ambient air parameters were taken into account and annual fuel reduction was considered to be a primary criterion, as an example. The improved methodology of the engine intake air cooling system designing based on the annual effect due to cooling was developed. It involves determining the optimal value of cooling capacity, providing the minimum system sizes at maximum rate of annual effect increment, and its rational value, providing a close to maximum annual effect without system oversizing at the second maximum rate of annual effect increment within the range beyond the first maximum rate. The rational value of design cooling capacity provides practically the maximum annual fuel saving but with the sizes of cooling systems reduced by 15 to 20% due to the correspondingly reduced design cooling capacity of the systems as compared with their values defined by traditional designing focused to cover current peaked short-term thermal loads. The optimal value of cooling capacity providing the minimum sizes of cooling system is very reasonable for applying the energy saving technologies, for instance, based on the thermal storage with accumulating excessive (not consumed) cooling capacities at lowered current thermal loads to cover the peak loads. The application of developed methodology enables revealing the thermal potential for enhancing the efficiency of any combustion engine (gas turbines and engines, internal combustion engines, etc.).

**Keywords:** combustion engine; intake air; cooling capacity; chiller; current thermal load; annual fuel reduction

## 1. Introduction

Fuel efficiency of combustion engines (gas turbines [1–3], diesel engines [4] and gas engines [5–7]) falls with raising an ambient air temperature at their intake. Gas turbines (GT) are especially sensitive to intake conditions [8–10]: a specific fuel consumption increases by 0.4 to 1.0 g/(kWh) for every 1K rise

in intake air temperature. A lot of ambient air cooling technologies were developed to enhance engine output [11–13]. The cheapest and most widespread in hot climatic conditions is a contact method by evaporation of water sprayed into air stream at the intake of GT compressor [14] and a novel contact cooling according to Maisotsenko cycle [15,16], but their efficiency is limited by the magnitudes of ambient air wet bulb temperature and they are not so effective in temperate climatic conditions.

Meantime the GT efficiencies are typically of 30 to 35% and a major part of the fuel energy consumed is dissipated to atmosphere as exhaust gases. Therefore, the use of exhaust heat from GT is a very effective trend in enhancing their overall efficiency [17,18]. Issuing from this, turbine intake air cooling (TIAC) in exhaust heat recovery chillers is a very perspective approach to improving the fuel efficiency of GT at increased intake ambient air temperatures [19–21]. Thus, cooling intake air by converting the heat of exhaust gas in chillers provides increasing the efficiency of GT with corresponding fuel saving at raised ambient air temperatures [22–24].

The absorption lithium-bromide chillers (ACh) are the most widely used in a hot climate [25–27]. They are characterized by a high efficiency: their coefficients of performance COP is 0.7 to 0.8 (COP is ratio of generated cooling capacity  $Q_0$ , kW, to the heat consumed  $Q_h$ , kW), environmentally friendly, and noise free [28–30]. The same advantages and ability to use a low potential heat with a bit less COP are peculiar for adsorption chillers [31,32]. The refrigeration vapor compression chillers require mechanical or electrical driving [33], while absorption and adsorption chillers use only waste heat.

Some authors have investigated the use of ACh to improve the efficiency of contact methods of cooling, in particular by cooling the water injected into the air stream; however, the most common way of cooling air at the inlet of the GT is the application of air coolers fed by ACh cooling capacity.

Many publications focused for improving ambient air processing by intensification of heat transfer processes in air coolers-evaporators [34] and condensers [35–37] of refrigeration chillers, in particular, through refrigerant recirculation to intensify heat transfer, increase heat flux and reduce temperature difference in intake air coolers as result [38,39], waste heat recovery technics for combined cooling, heating and power (CCHP), so-called trigeneration or integrated energy systems [40,41].

Some of principal technical innovations and methodological approaches in heat recovery: jet technologies [42–44], deep exhaust heat use [45–47] for increasing the available waste heat potential to be converted into refrigeration and others were developed for TIAC or might be successfully applied in TIAC to match current cooling demands [48–50], in particular, two-stage air cooling [51].

The intake air temperature depression  $\Delta t = t_{amb} - t_{a2}$ , influencing the efficiency of TIAC, depends on the ambient air temperature  $t_{amb}$  and a temperature  $t_{a2}$  of air cooled in chiller at the inlet of GT, which depends on the temperature of a coolant, i.e., on the type of chiller. In ACh of a simple cycle with high coefficients of performance COP is 0.7 to 0.8 and a temperature of chilled water  $t_w$  of about 7 °C an intake air can be cooled only to  $t_{a2} = 15$  °C. In the most simple in design and cheap refrigeration ejector chillers (ECh) that use refrigerants as low boiling coolant, the intake air can be cooled to lower temperatures  $t_{a2}$  is 7 to 10 °C at the temperatures of boiling refrigerant  $t_0$  ranging from 1 to 5 °C, but with low COP from 0.2 to 0.3 that requires raised amounts of exhaust gas heat.

It is quite reasonable to apply a highly efficient ACh as a high-temperature stage of intake air cooling from current ambient air temperatures  $t_{amb}$  to  $t_{a2} = 15$  °C and a less efficient ECh as a low-temperature stage for further subcooling air lower than 15 °C. The application of such hybrid intake air coolers is especially expedient for operation of GT in temperate climatic conditions. They are able to provide deep intake air cooling with corresponding increase of TIAC operation duration and much more annual effect as a result: fuel reduction or power output increase, compared to traditional cooling in ACh.

Such innovative two-stage ambient air cooling systems consist of chillers that convert the heat of exhaust gas into refrigeration in the form of coolant, feeding turbine intake air coolers, and could find effective application in different types of combustion engines: gas turbines [52,53], gas engines for combustion of biogas [54,55], stationary and marine power plants [56,57].

Many modern methods of analyses [58–60] are aimed to increase the effect gained due to ambient air processing, in particular, to reduce energy and fuel consumption. Some of such methods include calculation of cooling degree-hours (CDH) [14,61] and modified versions [62–64] to match current cooling duties according to actual climatic conditions as well as thermal demand management (TDM) [65,66] based on different criteria [67,68] to save energy in building conditioning, engine intake air cooling and combined cooling, heat and power.

Cooling degree-hour (CDH) calculations are widely used for evaluating the efficiency of application of ambient air cooling in site climatic conditions in power generation—combustion engine intake air cooling [63,64], as well as in air conditioning [62]. So as the performance efficiency of TIAC systems needs to be analyzed across the full range of operating conditions, the CDH number is used to determine the total amount  $\sum$ CDHs in a particular climate over a considered period.

The use of TIAC potential in terms of CDH provides easy calculation of fuel reduction and engine power output augmentation for any considered period. For this purpose a climatic characteristic of GT as dependence of specific fuel consumption  $b_e$ , g/(kWh), and GT power output  $P_e$ , kW, on intake air temperature are used.

The ambient air temperature and relative humidity distribution during year or any cooling period is very important input data for energy analyses and a design cooling load determination. The studies on the input ambient data when evaluating gas turbine inlet cooling are presented in [62–64].

Although many researchers consider the cumulative CDH profile along with time elapsed [62], only a few studies focus on analyzing the behavior of yearly cumulative cooling profiles in dependence on loading to determine a design cooling load [63,65].

All the typical methods, based on summarizing the number of CDH, issue from the assumption of a design cooling capacity as a sufficient to provide maximum cooling needs over the full range of yearly operating conditions [63]. Such an approach may lead to considerable oversizing of the chillers and the TIAC systems in the whole that requires to solve the problem of determining the correct design cooling load excluding oversizing, as it was shown in [69–71].

A design cooling capacity  $Q_0$  of TIAC system, on the one hand, has to cover intake air cooling, and needs to do so during as long a time of GT operation during a year as possible, which provides the greatest annual fuel reduction. On the other hand, a design cooling capacity  $Q_0$  should not be overestimated so that for the most part of the year a TIAC system would be able to operate at a high load level close to a design value. Otherwise low efficiency of TIAC system operation takes place, and on the contrary, when underestimating  $Q_0$ —insufficient turbine intake air cooling at high ambient temperatures.

Thus, the fuel efficiency of GT in temperate climatic conditions firstly might be considerably enhanced due to deep intake air cooling that needs the application of combined chillers and rational designing of TIAC systems to guarantee a close to maximum annual fuel saving, but without system overloading, as an alternative to their traditional designing to cover the maximum loading with inevitable system oversizing.

The goal of this investigation is to increase the fuel efficiency of GT by deep intake air cooling in combined absorption ejector TIAC systems with ACh as a high-temperature and ECh as a low-temperature cooling stages and through rational designing of the proposed systems.

## 2. Materials and Methods

A method of logical analysis [72,73] of the actual operation efficiency of TIAC systems in real varying environment, supplemented by the simplest numerical simulation that enables its easy application in designing practice of any ambient air cooling system, is behind this research and the design methodology proposed. The real input data on site actual climatic conditions (ambient air temperature  $t_{amb}$  and relative humidity  $\varphi_{amb}$ ) were taken by using the well-known programs, for instance “meteomanz” [74].



To avoid errors caused by the approximation of the current changeable effect gained due to cooling (fuel reduction, power output increase, etc.) at varying loading of TIAC systems in response to actual climatic conditions, the fluctuations of the last are considered through summarizing the current values of the effect and its evaluated by different rate of its annual value increment.

Thus, the novelty of the research methodological approach to analysis of the TIAC system operation efficiency consists of summation of the current changeable effect (fuel reduction, etc.) due to cooling air over the year as an annular effect (annual fuel saving). The rate of its increment according to cooling capacity is used as an indicator to efficient realization of cooling capacity generated.

To realize the methodological approach mentioned above the improved methodology of TIAC system designing based on the annual effect is developed. It involves additional stages to determine an optimal value of cooling capacity, providing the minimum system sizes at maximum rate of annual effect increment, and its rational value, providing a close to maximum annual effect without TIAC system oversizing at the second maximum rate of annual effect increment within the range beyond the first maximum rate.

The tradition methods of TIAC system designing is based on the approximation of varying current values of the effect in the form of cumulative effect characteristic built by the samples of corresponding current values of effect in dependence on loading. With this a design cooling load is selected about 20% higher than its value corresponding to the maximum of cumulative characteristic [65]. The most widespread methods of TIAC system designing are intended to provide the maximum values of current effect during a year or annual effect due to air cooling [63] and leads to overestimating design cooling capacity and TIAC system oversizing as a result.

A proposed designing methodology based on the approach of two maximum rates of annual effect increment is very quantitative and simple for realization in different types of energetic plants including combustion engines and air conditioning systems.

### 2.1. General Assumptions and Hypothesis

The assumptions adopted for the analysis of the operation efficiency of TIAC systems and their rational designing are as follows:

- The lowest temperature of air cooled in ACh of a simple cycle is assumed to be  $t_{a2} = 15\text{ }^{\circ}\text{C}$  and limited by minimum temperature difference of  $8\text{ }^{\circ}\text{C}$  between cooled air and chilled water leaving ACh at  $t_w = 7\text{ }^{\circ}\text{C}$  (water at the inlet of air cooler):  $t_{a2} = t_w + 8\text{ }^{\circ}\text{C}$ .
- In the case of using a refrigerant as a coolant in the air cooler the temperature difference between heat exchanging fluids is lower, 4 or  $5\text{ }^{\circ}\text{C}$ , falling in dependence of the refrigerant boiling point in air cooler within  $t_0$  of 2 to  $5\text{ }^{\circ}\text{C}$ . This leads to lower values of minimum temperature  $t_{a2}$  of air cooled in refrigerant chiller, for instance, 7 to  $10\text{ }^{\circ}\text{C}$  in ECh:  $t_{a2} = t_0 + (4\text{ or }5)\text{ }^{\circ}\text{C}$ .
- The last assumption regulates a joint operation of ACh and ECh in a two stage cooling air mode: to  $15\text{ }^{\circ}\text{C}$  in ACh and further subcooling to  $10\text{ }^{\circ}\text{C}$  in ECh of a stage absorption-ejector chiller (SAECh) and in cascade mode at lowered ambient air temperatures  $t_{amb}$  when ambient air temperature drops to  $t_{amb} = 15\text{ }^{\circ}\text{C}$  the excessive (not consumed) cooling capacity of ACh is used for cooling the condenser of ECh as a low cascade of cascade absorption-ejector chiller (CAECh).
- As well as proposed absorption-ejector TIAC systems are the advanced versions of typical basic absorption TIAC system, the economic comparison with the last might be done taking into account only the cost of extra heat exchangers of ECh (refrigerant evaporator-air cooler, refrigerant condenser, and ejector) with unchanged maintenance cost, personal, etc. Because of fluctuations in cost of heat exchangers of different manufacturers and a fuel especially the economic analysis is to be conducted for the concrete case. Thus, the considered method of designing focuses to provide just initial basic data as rational technical characteristics for further complicated detailed economic analysis.

The hypothesis accepted to prove novel approaches to the principles of proposed innovative TIAC system operation with account of actual climatic conditions are the following.

The fluctuations of current thermal loads on TIAC systems, caused by variable actual ambient air parameters, should be covered by the chiller with high coefficients of performance COP, i.e., by ACh with COP from 0.7 to 0.8 that provide cooling ambient air to 15 °C. The further subcooling of air down to 10 °C and lower is conducted within a comparatively stable range of loading and can be covered by less efficient ECh (COP is from 0.2 to 0.3) and more sensitive to load changes.

In temperate climatic conditions, when cooling load on ACh falls, the effect in reduced specific fuel consumption might be still considerably enlarged due to deeper cooling ambient air at the intake of GT to the temperatures from 7 to 10 °C, compared with its traditional cooling to 15 °C in ACh of a simple cycle. According to this hypothesis a deep GT intake air cooling is considered to be a perspective trend of enhancing turbine efficiency.

To provide deep cooling the absorption-ejector TIAC system operates as a stage system to conduct two-stage cooling air consequently to the temperature of 15 °C by chilled water from ACh and further subcooling to about 10 °C by boiling refrigerant from ECh.

At lowered ambient air temperatures, and thermal load on ACh accordingly, the excessive (not consumed) cooling capacity of ACh is used for cooling the condenser of ECh as the low cascade of cascade absorption-ejector chiller (CAECh) to provide deeper air cooling as compared with two-stage cooling air.

The following hypothesis to prove the novel approaches to designing of TIAC systems by the proposed method of determining a rational design cooling capacity are accepted.

The annual fuel reduction  $\sum B$  is used as a primary criterion.

To avoid the errors caused by the approximation of the current changeable effect gained due to cooling (fuel reduction, power output increase, etc.) at varying loading of TIAC systems in response to actual climatic conditions, the fluctuations of the last are considered through summarizing the current values of the effect and are evaluated by different rate of its annual value increment.

The summation of current values of changeable effect, gained due to air cooling at varying loading of TIAC system, over the considered period (year), allows considering their changes by the rate of its annual value increment (annual fuel reduction, power output increase, etc.) in response to design TIAC system cooling capacities.

The optimal value of cooling capacity, providing the minimum TIAC system sizes, is associated with the maximum rate of annual effect increment over the overall range of annual effect increment.

The rational value of TIAC system design cooling capacity, providing a close to maximum annual effect without TIAC system oversizing, is associated with the second maximum rate of annual effect increment within the range beyond the first maximum rate.

## 2.2. The Computation Algorithm

The cooling potential of GT intake air is estimated by cooling degree hours (CDH) calculated as air temperature depression  $\Delta t = t_a - t_{a2}$  multiplied by the corresponding duration  $\tau$  in hours:  $CDH = \Delta t \cdot \tau$ , K·h. The summation of current numbers  $CDH = \Delta t \cdot \tau$ , K·h for a year (month) gives an annual (monthly) intake air cooling potential:  $\Sigma CDH = \Sigma(\Delta t \cdot \tau)$ , K·h.

The real input data on site actual ambient air temperature  $t_{amb}$  were taken by using the program “meteomanz” [74].

The use of ambient air cooling potential in terms of CDH provides easy calculation of annual or monthly fuel reduction  $B$  or other effect, for instance, annual power energy production or refrigeration energy generation per estimated time period. In the present investigation the climatic characteristics of GT as dependence of specific (or total) fuel consumption  $b_e$  on intake air temperature are used. With this, the CDH numbers are multiplied by the value of decrease  $\Delta b_e$  in specific fuel consumption for every 1K drop in intake air temperature,  $\Delta b_e / \Delta t$ , and by turbine power output  $P_e$  [61,71]:

- current values of total fuel reduction per an hour

$$B = CDH (\Delta b_e / \Delta t) \cdot P_e$$

or specific fuel reduction (for 1 kW turbine power output)

$$b = CDH (\Delta b_e / \Delta t) \quad (1)$$

- annual total fuel reduction

$$\Sigma B = \Sigma CDH (\Delta b_e / \Delta t) \cdot P_e$$

or annual specific fuel reduction (for 1 kW turbine power output)

$$\Sigma b = \Sigma CDH (\Delta b_e / \Delta t) \quad (2)$$

A total cooling capacity  $Q_0$ , required for cooling air with flow rate  $G_a$ :

$$Q_0 = c_a \xi \cdot \Delta t_a \cdot G_a \quad (3)$$

where  $\Delta t_a = t_a - t_{a2}$ —depression of ambient air temperature;  $t_{a2}$ —temperature of cooled air at the air cooler outlet;  $\xi$ —specific heat ratio of the total heat (latent and sensible) rejected from air during cooling to its sensible heat;  $c_a$ —specific heat of humid (moist) air, kJ/(kg·K).

To simplify calculations and to apply their results for any total cooling capacity  $Q_0$  and GT power output, it is convenient to carry out the calculations and present their results in relative (specific) value per unit air mass flow rate ( $G_a = 1$  kg/s)—in the form of specific cooling capacity:  $q_0 = Q_0/G_a$ , kW/(kg/s), or kJ/kg, as well as fuel reduction in specific (relative) values  $\Sigma b$  for 1 kW power output of GT. For simplifying the application of calculation results for GT with various values of decrease  $\Delta b_e$  in specific fuel consumption for every 1 °C drop in intake air temperature the value of  $\Delta b_e / \Delta t = 1.0$  g/(kWh·K) was assumed. Therefore, if the real value for the concrete GT, for instance, is  $\Delta b_e / \Delta t = 0.35$  g/(kWh·K), the annual specific fuel reduction  $\Sigma b$  (2) should be multiplied by 0.35.

A specific cooling capacity  $q_0$ , required for cooling air of unit mass flow rate  $G_a = 1$  kg/s:

$$q_0 = Q_0/G_a = c_a \xi \cdot \Delta t_a \quad (4)$$

An improved method of TIAC system rational designed based on the annular fuel reduction  $\Sigma B$  curve dependence on cooling capacity  $Q_0$  as  $\Sigma B = f(Q_0)$  or in specific (relative) values  $\Sigma b = f(q_0)$  for 1 kW power output of GT is developed to avoid oversizing.

The well-known method of design cooling load calculation based on maximum value of annular fuel reduction  $\Sigma B$  proceeding from annual CDH number as a primary criterion is used as the first stage of developed methodology. It has been supplemented by addition stages focused to determine a precise value of rational design cooling capacity that enables avoiding TIAC system oversizing.


A design specific cooling capacity value  $q_{0,opt}$  (corresponding to total cooling capacity value  $Q_{0,opt}$ ) that provides a maximum rate  $\Sigma b/q_0$  of annual fuel reduction increment and corresponding annual specific fuel reduction  $\Sigma b_{opt}$  (corresponding to total values  $\Sigma B/Q_0$  and  $\Sigma B_{opt}$ ), and assumed as optimal value, is determined at the second stage of calculation procedure.

The third stage focuses to calculate the maximum rate of annual fuel reduction increment  $\Sigma b/q_0$  but in a remaining range beyond the optimal annual specific fuel reduction  $\Sigma b_{opt}$ :  $[\Sigma b - \Sigma b_{opt}] / q_0$ , where  $\Sigma b > \Sigma b_{opt}$  or corresponding total values  $\Sigma B_{opt}$ :  $[\Sigma B - \Sigma B_{opt}] / Q_0$ , where  $\Sigma B > \Sigma B_{opt}$ . A cooling capacity  $q_{0,rat}$ , corresponding to the second maximum rate of annual fuel reduction increment  $\Sigma b/q_0$ , is considered to be a precise value of rational design specific cooling capacity  $q_{0,rat}$  or rational design total cooling capacity value  $Q_{0,opt}$ .

The fourth stage of proposed methodology is aimed to calculate the annual fuel reduction  $\sum b_{\text{rat}}$  or  $\sum B_{\text{rat}}$  close to its maximum value at a precise value of rational design cooling capacity  $q_{0,\text{rat}}$  or  $Q_{0,\text{rat}}$ , excluding system oversizing. Details of the calculation procedure have been presented in Appendix A.


### 3. Results

The GT operation climatic conditions are characterized by large fluctuations of ambient air parameters: temperature  $t_{\text{amb}}$ , relative  $\varphi_{\text{amb}}$  and absolute  $d_{\text{amb}}$  humidity (Figure 1).



**Figure 1.** Ambient air temperatures  $t_{\text{amb}}$ , relative  $\varphi_{\text{amb}}$  and absolute  $d_{\text{amb}}$  humidity in 2017, Mykolayiv region (southern Ukraine).


The fluctuation of ambient air parameters causes large changes of specific cooling capacities  $q_0$  required for cooling ambient air of unit air mass flow rate,  $G_a = 1 \text{ kg/s}$ , at the intake of GT (changes in current specific thermal loads on cooling system) accordingly (Figure 2).



**Figure 2.** Changes of specific cooling capacities  $q_{0,7}$ ,  $q_{0,10}$  and  $q_{0,15}$  required for cooling ambient air with unit mass flow rate of 1 kg/s from its actual temperature  $t_{\text{amb}}$  to  $t_2 = 7, 10$  and  $15 \text{ }^\circ\text{C}$ .

Such large yearly variations of specific cooling capacities  $q_{0,7}$ ,  $q_{0,10}$  and  $q_{0,15}$ , required for cooling ambient air from current air temperatures  $t_a$  to target temperatures of cooled air  $t_{a2} = 7, 10$ , and  $15 \text{ }^\circ\text{C}$  reveal the actual problem to choose a design cooling capacity of the chillers and rational chiller compound of TIAC system to cover actual cooling duties without its oversizing and provide close to maximum annual fuel reduction.

Traditionally a turbine intake air is cooled to the temperature  $t_{a2} = 15 \text{ }^\circ\text{C}$  by a chilled water with a temperature of  $7 \text{ }^\circ\text{C}$  from absorption lithium-bromide chiller (ACh) of a simple cycle with a high coefficient of performance COP from 0.7 to 0.8 (Figure 3).



**Figure 3.** A scheme of gas turbine intake air cooling system with absorption lithium-bromide chiller (ACh) using the heat of exhaust gas: AC—air cooler.

As mentioned above, the lowest temperature of air cooled in ACh of a simple cycle is about 15 °C and limited by the temperature of chilled water of 7 °C at the inlet of air cooler.


To provide turbine intake air cooling to lower temperature of about 10 °C with corresponding increment of fuel saving the refrigerant with lower boiling point can be used as a coolant in the inlet air cooler and the ECh applied as the most simple in design and cheap, but not so high efficient as ACh: its COP is 0.2 to 0.3 versus COP of 0.7 for ACh.

So as the COP of ECh falls with lowering the boiling temperature of refrigerant, in order to keep the COP at the level of about 0.3 the refrigerant boiling temperature is to be about  $t_0$  from 4 to 5 °C and a thermal load on ECh should be restricted by its range, referred to subcooling the air, previously pre-cooled in high efficient ACh.

Issuing from this approach, a novel two-stage TIAC system has been proposed (Figure 4). Apparently it is reasonable to cool intake air from current ambient air temperature  $t_{amb}$  to  $t_{a2} = 15$  °C in ACh with high coefficient of performance COP from 0.7 to 0.8, but further deep cooling air from  $t_{a2} = 15$  °C down to  $t_{a2} = 10$  °C is possible by boiling refrigerant from ECh, i.e., in combined two-stage absorption-ejector chiller (AECh) (Figure 4). The use of ECh as a second stage of TIAC with previous ambient air precooling is caused by its low coefficient of performance COP from 0.2 to 0.3 that requires enlarged values of heat generated in exhaust boiler in the form of hot water or steam.

Further enhancing the efficiency of TIAC systems and the effect, as turbine fuel saving for example, gained due to their application, especially in the case of their running in temperate climatic conditions, is still depended on lowering the intake air temperature, limited by temperature of coolant in the air cooler. In the case of ECh, as low-temperature stage of two-stage AECh (SAECh), a decrease in refrigerant boiling temperature to  $t_0$  of 2 to 3 °C is accompanied by dropping its COP to 0.2 and lower. To compensate for a negative effect of decreasing a refrigerant boiling temperature  $t_0$  in ejector thermodynamic cycle, the refrigerant condensing temperature  $t_c$  should be decreased too. This might be realized through cooling the condenser of ECh by chilled water from ACh with temperature of about 7 °C or by returned chilled water leaving the intake air cooler (high-temperature stage AC<sub>HT</sub> of hybrid intake air cooler) with temperature of about 10 to 12 °C. The last variant is more efficient due to the use of chilled water of enlarged flow rate in intake air cooler that is accompanied by decreasing its temperature arise and leads to increasing a heat flux in air cooler and reducing its dimensions as a result.






**Figure 4.** A scheme of two-stage gas turbine intake air cooling system in stage absorption-ejector chiller (SAECh): AC<sub>HT</sub>—high-temperature stage of air cooler; AC<sub>LT</sub>—low-temperature stage of air cooler; Exp.Valve—expansion valve.

The reserves for the use of cooling capacity of ACh for enhancing the efficiency of ACh are proceeded from the variation of current thermal loads on TIAC system. At lowered ambient air temperatures, and thermal load on TIAC system accordingly, the excessive cooling capacity of ACh can be used for cooling the condenser of ECh to provide deeper air cooling to 7 °C and lower due to lowered refrigerant boiling temperature  $t_0$  of 2 to 3 °C as compared with two-stage cooling air to the temperature of 10 °C (at  $t_0$  of 4 to 5 °C) in a stage absorption-ejector chiller (SAECh).

In this case, the ECh operates as the low cascade of cascade absorption-ejector chiller (CAECh) to provide deeper cooling the intake air (to 7 °C and lower) previously pre-cooled to the temperature of 15 °C in the first high-temperature stage of air cooler by ACh (Figure 5).




**Figure 5.** A scheme of two-stage gas turbine intake air cooling system in stage cascade absorption-ejector chiller (SCAECh).

Such functioning of ECh as the low-temperature stage in SAECh to provide intake air cooling to 10 °C at increased ambient air temperatures and as low cascade of CAECh to provide deeper intake air cooling to 7 °C and lower at decreased ambient air temperature enables matching daily and seasonal fluctuations in thermal loads and efficient operation of TIAC systems in actual site climatic conditions.

In this case, we deal with universal combined stage-cascade absorption-ejector chiller (SCAECh), functioning as SAECh at increased ambient air temperatures and as SCAECh at its decreased temperatures or even as CAECh at ambient air temperatures close to 15 °C and lower. Such SCAECh provides a maximum effect, gained due to deep TIAC and matching daily and seasonal fluctuations in thermal loads, especially in temperate climatic conditions.

To determine a rational design thermal load on TIAC system that provides close to maximum annual values of fuel reduction the characteristic curves of annual values of CDH versus specific cooling capacity  $q_0$  (per unit air mass flow rate  $G_a = 1$  kg/s) and total fuel reduction  $\Sigma B$  versus overall cooling capacity  $Q_0$  (per total air mass flow rate  $G_a$ ) to target temperatures of cooled air  $t_{a2}$ : 7 and 10 °C—in AECh; 15 °C—in ACh for climatic conditions in Mykolayiv region (southern Ukraine) are calculated as the first, traditional, stage of TIAC system designing (Figure 6).



**Figure 6.** The annual values of CDH versus specific cooling capacity  $q_0$  (a) and total fuel reduction  $\Sigma B$  versus overall cooling capacity  $Q_0$  (b) for  $t_{a2}$ : 7 and 10 °C—in AECh; 15 °C—in ACh.


The calculations are carried out for GT of rated power output  $N_{elSO} = 10$  MW and with account to assumption that a reduction of air temperature  $\Delta t_a$  by 1K leads to a decrease in specific fuel consumption  $\Delta b_e$  by 1.0 g/(kWh), as it was assumed for easy calculation of fuel reduction  $\Sigma B$  and  $\Sigma b$  for another value of  $\Delta b_e/\Delta t_a$ .

As it was mentioned above, in order to simplify calculations and to apply their results for any total cooling capacity  $Q_0$  and GT power output, it is convenient to carry out the calculations and present their results in relative (specific) value per unit air mass flow rate ( $G_a = 1$  kg/s)—in the form of specific cooling capacity:  $q_0 = Q_0/G_a$ , kW/(kg/s), or kJ/kg, as well as annual fuel reduction in specific (relative) values  $\Sigma b$  for 1 kW power output of GT.

The annual values of GT specific fuel reduction  $\Sigma \Delta b$  (for 1 kW of GT power) due to intake air cooling from ambient air temperatures  $t_{amb}$  to  $t_{a2} = 7, 10$  and 15 °C by chillers with various specific cooling capacities  $q_0$  (per unit air mass flow rate  $G_a = 1$  kg/s) for climatic conditions in Mykolayiv region (southern Ukraine) are presented in Figure 7.

Figures 6 and 7 show that intake air cooling in AECh to  $t_{a2} = 10$  °C provides more than 50% greater annual reduction in fuel consumption compared to cooling air to  $t_{a2} = 15$  °C in ACh. As Figure 7 shows, a specific cooling capacity  $q_{0.10}$  is 33 to 35 kW/(kg/s), or kJ/kg, provide cooling ambient air from the current temperatures  $t_a$  to  $t_{a2} = 10$  °C with annual specific fuel reduction  $\Sigma b_{10}$  of 47 to 48 kg/kW (Figure 7) with corresponding overall cooling capacity  $Q_{0.10}$  of 1300 to 1400 kW providing a total fuel reduction  $\Sigma B_{10}$  of 470 to 480 t (Figure 6) that is close to their maximum value at noticeable high rate of their annual increment. While beyond the values  $Q_{0.10}$  of 1300 to 1400 kW or  $q_{0.10}$  of 33 to 35 kW/(kg/s)

a rate of annual fuel reduction increment  $\Sigma B$  or  $\Sigma b$  is negligible, the range of corresponding cooling capacities  $Q_0$  or  $q_0$  needed is wide that approves a considerable chiller oversizing. Thus, the precise values of design cooling capacities  $Q_0$  or  $q_0$  are to be determined for appropriately sized TIAC system.




**Figure 7.** The annual values of specific fuel reduction  $\Sigma\Delta b_e$  against specific cooling capacity  $q_0$  at different temperatures of cooled air  $t_{a2}$ : 7 and 10 °C—in AECh; 15 °C—in ACh.


Furthermore, with arising a target temperature of cooled air  $t_{a2}$  to 15 °C it is more problematic to select precise value of rational design cooling capacity  $Q_{0.15rat}$  or  $q_{0.15rat}$  so as behavior of the curve  $\Sigma B = f(Q_0)$  or  $\Sigma b = f(q_0)$  becomes moderate (Figures 6 and 7). Therefore the original method of determining a design cooling capacity has been modified by adding the stages aimed for calculation of optimal design cooling capacity  $Q_{0,opt}$  or  $q_{0,opt}$  corresponding to a maximum rate of annual fuel reduction increment  $\Sigma B/Q_0$  or  $\Sigma b/q_0$  as intermediate stage (Figure 8) for determining the precise value of rational design specific cooling capacity  $q_{0,rat}$  (Figures 9–11).

The points  $O_{15}$  and  $O_{10}$  on the TIAC cumulative characteristics of dependence of annual specific fuel reduction  $\Sigma b_{15}$  and  $\Sigma b_{10}$  on the specific cooling capacities  $q_{0.15}$  and  $q_{0.10}$  are determined according to optimal values of design specific cooling capacities  $q_{0.15opt}$  and  $q_{0.10opt}$ , corresponding to maximum values of ratios  $\Sigma B/Q_0$  or  $\Sigma b/q_0$ , i.e., maximum rate of annual fuel reduction increment.


As Figure 8 shows, a maximum rate of annual specific fuel reduction increment  $\Sigma b/q_{0.15}$  due to cooling air to  $t_{a2} = 15$  °C takes place at the optimal design specific cooling capacity  $q_{0.15opt} = 16$  kW/(kg/s) and provides the annual specific fuel reduction  $\Sigma b_{15opt} = 22.5$  kg/kW considerably less than its maximum value  $\Sigma b_{15max} = 27$  kg/kW. With cooling air targeting  $t_{a2} = 10$  °C the optimal specific cooling capacity  $q_{0.10opt} = 27$  kW/(kg/s) provides  $\Sigma b_{10opt} = 42$  kg/kW less versus  $\Sigma b_{10max} = 49$  kg/kW.




**Figure 8.** Annual specific fuel reduction  $\Sigma b$  and its relative increment  $\Sigma b/q_0$  due to cooling ambient air to  $t_{a2} = 15$  °C (a) and 10 °C (b) against specific cooling capacity  $q_0$ :  $q_{0,opt}$  and  $\Sigma b_{opt}$ —optimal values.



**Figure 9.** Relative increments of annual specific fuel reduction  $\Sigma b/q_0$  and  $(\Sigma b - \Sigma b_{opt})/q_0$  for  $t_{a2} = 15\text{ }^\circ\text{C}$  (a) and  $10\text{ }^\circ\text{C}$  (b) against specific cooling capacity  $q_0$ .



**Figure 10.** Annual specific fuel reduction  $\Sigma b$  and relative increment of annual specific fuel reduction  $(\Sigma b - \Sigma b_{opt})/q_0$  for  $t_{a2} = 15\text{ }^\circ\text{C}$  (a) and  $10\text{ }^\circ\text{C}$  (b):  $-(\Sigma b - \Sigma b_{opt})/q_0$ .



**Figure 11.** Relative increment of annual specific fuel reduction  $\Sigma b/q_0$  and annual specific fuel reduction  $\Sigma b$  due to cooling air to  $t_{a2} = 7, 10$  and  $15\text{ }^\circ\text{C}$  against a cooling capacity needed  $q_0$  (2 stage of methodology).

To achieve close to maximum annual specific fuel reduction  $\Sigma b_{15opt}$  at more precise value of rational cooling capacity  $q_{0.rat}$  without oversizing the chiller, it is proposed to determine the maximum rate of annual specific fuel reduction increment as  $(\Sigma b - \Sigma b_{opt})/q_{0.15}$  in the range of  $\Sigma b_{15}$  beyond its value  $\Sigma b_{15opt} = 22.5\text{ kg/kW}$  corresponding to optimal design capacity  $q_{0.15opt} = 16\text{ kW/(kg/s)}$  for cooling air to  $t_{a2} = 15\text{ }^\circ\text{C}$  as well as beyond  $\Sigma b_{10opt} = 42\text{ kg/kW}$  corresponding to  $q_{0.10opt} = 27\text{ kW/(kg/s)}$  for  $t_{a2} = 10\text{ }^\circ\text{C}$  (Figures 9 and 10).

Here:  $q_{0,opt}$ —optimal,  $q_{0,rat}$ —rational and  $q_{0,max}$ —maximum values; points  $O_{15}$  and  $O_{10}$  correspond to  $q_{0.15opt}$  and  $q_{0.10opt}$ ;  $R_{15}$  and  $R_{10}$ —for  $q_{0.15rat}$  and  $q_{0.10rat}$ ;  $\Delta q_{0.15} = q_{0.15max} - q_{0.15rat}$  and  $\Delta q_{0.10} = q_{0.10max} - q_{0.10rat}$ —reduction of design specific cooling capacity  $q_0$ .

As Figures 9 and 10 show, a maximum rate of annual specific fuel reduction increment  $(\sum b - \sum b_{opt})/q_{0.15}$  when cooling ambient air to  $t_{a2} = 15$  °C takes place at specific cooling capacity  $q_{0.15rat} = 24$  kW/(kg/s) and provides annual specific fuel reduction  $\sum b_{15rat}$  very close to its maximum value  $\sum b_{15max} = 27$  kg/kW, but achieved at a rational cooling capacity  $q_{0.15rat} = 24$  kW/(kg/s) that is less than its oversized maximum value  $q_{0.15max} = 31$  kW/(kg/s) by  $\Delta q_{0.15} = q_{0.15max} - q_{0.15rat}$  of about 7 kW/(kg/s), i.e., more than 20%. When cooling ambient air to  $t_{a2} = 10$  °C a maximum value of  $(\sum b - \sum b_{opt})/q_{0.10}$  takes place at the rational cooling capacity  $q_{0.10rat} = 37$  kW/(kg/s) and provides annual specific fuel reduction  $\sum b_{10rat} = 47$  kg/kW that is close to its maximum value  $\sum b_{10max} = 48$  kg/kW and achieved at a rational cooling capacity  $q_{0.10rat} = 37$  kW/(kg/s) less than its oversized maximum value  $q_{0.10max} = 44$  kW/(kg/s) by  $\Delta q_{0.10} = q_{0.10max} - q_{0.10rat}$  of about 9 kW/(kg/s), i.e., approximately 20% less. The points  $R_{15}$  and  $R_{10}$  on the TIAC cumulative characteristics of dependence of annual specific fuel reduction  $\sum b_{15} = f(q_0)$  and  $\sum b_{10} = f(q_0)$  on the specific cooling capacities  $q_{0.15}$  and  $q_{0.10}$  are determined according to rational values of design specific cooling capacities  $q_{0.15rat}$  and  $q_{0.10rat}$ , calculated at the stage 3 of design methodology. As it is seen, the values of rational annual specific fuel reduction  $\sum b_{15rat}$  and  $\sum b_{10rat}$ , determined proceeding from the points  $R_{15}$  and  $R_{10}$ , are very close to their maximum values  $\sum b_{15max}$  and  $\sum b_{10max}$ .

Graphs in Figures 9 and 10 allow users to match current cooling duties and provide minimum sizing system at maximum rate of annular cooling effect increment due to operation at optimal cooling capacity  $q_{0.10opt}$  (Figure 9) or to peak cooling needs without oversizing due to running at rational cooling capacity  $q_{0,rat}$  (Figure 10).


#### 4. Discussion

To generalize the results of analysing the efficiency of engine intake air cooling in TIAC systems, using chillers of different types, the optimal and rational design thermal loads for cooling intake air to target temperatures 7 to 15 °C in actual site climatic conditions were calculated step-by-step year round on the basis of the proposed novel methodology (Figures 11–14).


As Figure 11 shows, a maximum rate of annual specific fuel reduction  $\sum b/q_0$  due to cooling ambient air to the temperatures  $t_{a2} = 7, 10$  and 15 °C takes place at the optimal design specific cooling capacities (points  $O_7, O_{10}, O_{15}$ ):  $q_{0.7opt} = 33$  kW/(kg/s),  $q_{0.10opt} = 27$  kW/(kg/s) and  $q_{0.15opt} = 16$  kW/(kg/s), which provide annual specific fuel reduction  $\sum b_{7opt} = 56$  kg/kW,  $\sum b_{10opt} = 42$  kg/kW and  $\sum b_{15opt} = 22$  kg/kW considerably less than their maximum values. These values of  $\sum b_{opt}$  are used to determine the range of annual specific fuel reduction  $(\sum b - \sum b_{opt})$  beyond their optimal values  $\sum b_{opt}$  to calculate the ratios  $(\sum b - \sum b_{opt})/q_0$  that characterize the rate of annual specific fuel reduction beyond the optimal values  $\sum b_{opt}$  and their maximum values correspond to rational design specific cooling capacities:  $q_{0,rat}$ .

As Figures 11 and 12 show, a maximum rate of annual fuel reduction increment  $(\sum b - \sum b_{opt})/q_0$  in the ranges beyond their optimal values  $\sum b_{opt}$  (Figure 11) is characterized by maximum values of ratios  $(\sum b - \sum b_{opt})/q_0$  which correspond to rational design specific cooling capacities  $q_{0,rat}$  when cooling ambient air to the temperatures  $t_{a2} = 7, 10$  and 15 °C:  $q_{0.7rat} = 41$  kW/(kg/s),  $q_{0.10rat} = 35$  kW/(kg/s) and  $q_{0.15rat} = 24$  kW/(kg/s) (stage 3, Figure 12). These values of rational design specific cooling capacities  $q_{0,rat}$  determine the position of the points  $R_7, R_{10}$  and  $R_{15}$  on the TIAC cumulative characteristics of dependence of annual specific fuel reduction  $\sum b_7 = f(q_0)$ ,  $\sum b_{10} = f(q_0)$  and  $\sum b_{15} = f(q_0)$  and corresponding rational annual specific fuel reduction  $\sum b_{7rat}$ ,  $\sum b_{10rat}$  and  $\sum b_{15rat}$ , calculated at the stage 4 of design methodology (Figure 13).


As it is seen, the values of rational annual specific fuel reduction  $\sum b_{7rat}$ ,  $\sum b_{10rat}$  and  $\sum b_{15rat}$ , determined proceeding from the points  $R_7, R_{10}$  and  $R_{15}$ , are very close to their maximum values.



**Figure 12.** Relative increments of annual specific fuel reduction  $\Sigma b/q_0$  and  $(\Sigma b - \Sigma b_{opt})/q_0$  due to cooling air  $t_{a2} = 7, 10$  and  $15^\circ\text{C}$  against specific cooling capacities needed  $q_0$  (3 stage):  $-\Sigma b/q_0$ ;  $-(\Sigma b - \Sigma b_{opt})/q_0$ .



**Figure 13.** Annual specific fuel reduction  $\Sigma b$  and its relative increments  $(\Sigma b - \Sigma b_{opt})/q_0$  for  $t_{a2} = 7, 10$  and  $15^\circ\text{C}$ :  $\Delta q_0$ —reduction of design specific cooling capacity;  $-(\Sigma b - \Sigma b_{opt})/q_0$ .




**Figure 14.** Annual values of specific fuel reduction  $\Sigma b$  against specific cooling capacities  $q_0$  for  $t_{a2} = 7, 10$  and  $15^\circ\text{C}$ :  $\Delta q_0$ —reduction of design specific cooling capacity.

As Figure 13 shows, a maximum rate of annual specific fuel reduction increment  $(\Sigma b - \Sigma b_{opt})/q_0$  when cooling ambient air to  $t_{a2} = 15^\circ\text{C}$  takes place at specific cooling capacity  $q_{0.15rat} = 24 \text{ kW}/(\text{kg}/\text{s})$  and provides annual specific fuel reduction  $\Sigma b_{15rat}$  very close to its maximum value  $\Sigma b_{15max} = 26 \text{ kg}/\text{kW}$ , but achieved at a rational cooling capacity  $q_{0.15rat}$  less than its oversized maximum value  $q_{0.15max} =$

31 kW/(kg/s) by  $\Delta q_{0.15} = q_{0.15\max} - q_{0.15\text{rat}}$  of about 7 kW/(kg/s), i.e., more than 20%. When cooling ambient air to  $t_{a2} = 10^\circ\text{C}$  a maximum value of  $(\Sigma b - \Sigma b_{\text{opt}})/q_{0.10}$  takes place at the rational cooling capacity  $q_{0.10\text{rat}} = 35$  kW/(kg/s) and provides annual specific fuel reduction  $\Sigma b_{10\text{rat}} = 47$  kg/kW that is close to its maximum value  $\Sigma b_{10\max} = 49$  kg/kW and achieved at a rational cooling capacity  $q_{0.10\text{rat}}$  less than its oversized maximum value  $q_{0.10\max} = 44$  kW/(kg/s) by  $\Delta q_{0.10} = q_{0.10\max} - q_{0.10\text{rat}}$  of about 9 kW/(kg/s), i.e., approximately 20% less.

The values of rational annual specific fuel reduction  $\Sigma b_{7\text{rat}}$ ,  $\Sigma b_{10\text{rat}}$  and  $\Sigma b_{15\text{rat}}$ , proceeding from the points  $R_7$ ,  $R_{10}$  and  $R_{15}$ , determined according to rational cooling capacities  $q_{0,\text{rat}}$ , are very close to their maximum values, but achieved at rational cooling capacities  $q_{0,\text{rat}}$  less than their oversized maximum values by about 20% (Figure 14).

To generalize the results of analysing the efficiency of engine intake air cooling in TIAC systems by chillers of different types the TIAC cumulative characteristics of dependence of annual specific fuel reduction  $\Sigma b = f(q_0)$  on the specific cooling capacities  $q_0$  are presented in relative values as referred to their maximum values, selected on the basis of traditional methods of designing, i.e., as  $\Sigma b/b_{\max} = f(q_0/q_{0,\max})$  (Figure 15).



**Figure 15.** Relative values of annual fuel reduction  $\Sigma b/b_{\max}$  against relative cooling capacities  $q_0/q_{0,\max}$  needed for cooling ambient air to  $t_{a2} = 7, 10$  and  $15^\circ\text{C}$ .

As shown in Figure 15, the application of developed novel methodology allows to determine the precise values of rational design specific cooling capacities  $q_{0,\text{rat}}$  (corresponding overall values  $Q_{0,\text{rat}}$ ) of TIAC systems that provide annual fuel reduction very close to their maximum values, but achieved at cooling capacities less than the values, defined by traditional methods issuing from maximum yearly thermal loads or maximum annual effect due to intake air cooling, by about 20%.

As well as the proposed absorption-ejector TIAC systems, there are the advanced versions of typical basic absorption TIAC system, the economic comparison, where the latter might be done by taking into account only the cost of extra heat exchangers of ECh (refrigerant evaporator-air cooler, refrigerant condenser and ejector) with unchanged maintenance cost, personal costs, etc.

As a basic variant, the GT of power output of 10 MW and air mass flow rate  $G_a = 40$  kg/s might be accepted for easy recalculation for turbines with other characteristics. According to Figure 14  $q_{0.10\text{rat}} = 35$  kW/(kg/s) for TIAC system with AECh and  $q_{0.15\text{rat}} = 24$  kW/(kg/s) for traditional ACh or their total values  $Q_{0.10\text{rat}} = 1400$  kW and  $Q_{0.15\text{rat}} = 960$  kW for air mass flow rate  $G_a = 40$  kg/s with corresponding annual specific fuel reduction  $\Sigma b_{10\text{rat}} = 47$  kg/kW and  $\Sigma b_{15\text{rat}} = 26$  kg/kW or annual total fuel reduction  $\Sigma B_{10\text{rat}} = 470$  t and  $\Sigma B_{15\text{rat}} = 260$  t. Proceeding from these data, the value of the total cooling load on low temperature ECh  $Q_{0.10-15\text{rat}} = Q_{0.10\text{rat}} - Q_{0.15\text{rat}}$  i.e., 440 kW, provides additional annual fuel reduction  $\Sigma B_{10-15\text{rat}} = \Sigma B_{10\text{rat}} - \Sigma B_{15\text{rat}}$  about 210 t as compared with traditional TIAC system with ACh. Thus, the cooling capacity of refrigerant evaporator-air cooler of ECh  $Q_{0.10-15\text{rat}} = 440$  kW and of

refrigerant condenser  $Q_{\text{condenser}} = Q_{0.10-15rat} (1 + \text{COP})$ , i.e., about 1760 kW, where COP of ECh can be accepted as 0.3 [42,43]. Taking into account the cost of extra heat exchangers of ECh about 150,000\$ according to [75] and including addition 10% increase for ejector and 10% for their mounting the cost of addition equipment of ECh is about 180,000\$. On the other hand, the cost of gas fuel annually saved is about \$45,000 (proceeding from the price of gas \$150 per 1000 m<sup>3</sup>) and the payback period is about four years.

Because of the fluctuations in cost of heat exchangers of different manufacturers and the price of the gas fuel especially the economic analysis is to be conducted for the concrete case. Thus, we use the considered method of designing focuses to provide just initial basic data as rational technical characteristics for further complicated detailed economic analysis.

The proposed approach and a novel methodology of rational designing of engine intake air cooling systems enables saving about 20% of financial expenses and to cover actual yearly cooling duties without cooling system oversizing and unproductive decrease of engine power output to overcome the intake air pressure drop in oversized air coolers.

Such a method is quite quantitative to evaluate the effect due to cooling and select the rational design cooling capacity and estimate a decrease in sizes of chillers.

## 5. Conclusions

The efficiency of cooling ambient air at the inlet of gas turbines in temperate climatic conditions by waste heat recovery chillers, using the exhaust gas heat, was analyzed and reserves for its enhancing through deep cooling were revealed.

The gas turbine intake air cooling by combined absorption-ejector chillers (AECh) with ACh as a high temperature cooling stage and ECh as a low temperature cooling stage was proposed. It was shown that turbine intake air cooling to about 7 to 10 °C in temperate climatic conditions by combined absorption-ejector chillers provides an annual fuel saving of about 50% greater than its value gained due to traditional air cooling to about 15 °C in absorption lithium-bromide chiller of a simple cycle.

As a result, a novel trend in engine intake air cooling in temperate climatic conditions by two-stage cooling in chillers of combined type has been proposed.

A method of logical analysis of the actual operation efficiency of turbine intake air cooling systems in site varying environment, supplemented by the simplest numerical simulation, was used to synthesize new solutions. The real input data on site actual climatic conditions (ambient air temperature  $t_{amb}$  and relative humidity  $\varphi_{amb}$ ) were taken by using the well-known program "meteomanz" [74].

The annual fuel reduction was considered to be a primary criterion as an example.

The novelty of the research methodological approach to analysis of the TIAC system operation efficiency consists of summation of the current changeable effect (fuel reduction) due to cooling air over the year as an annular effect (annual fuel saving). The rate of its increment according to cooling capacity is used as an indicator to efficient realization of the design cooling capacity.

The improved methodology of TIAC system designing, based on this methodological approach, is developed. It involves the stages to determine an optimal value of cooling capacity, providing the minimum system sizes at maximum rate of annual effect increment, and its rational value, providing a close to maximum annual effect without TIAC system oversizing at the second maximum rate of annual effect increment within the range beyond the first maximum rate.

Such a method is quite quantitative when evaluating the effect due to cooling, selecting design cooling capacity, and estimating a decrease in sizes of chillers.

The rational value of design cooling capacity (thermal load) provides practically maximum annual fuel saving but with reduced by about 15 to 20% sizes of cooling systems due to correspondingly reduced design cooling capacity of the systems as compared with their values defined by traditional designing focused to cover maximum current thermal loads.

The method allows users to peak maximum cooling needs without oversizing system or provide minimum sizing TIAC system at maximum rate of annular cooling effect. The last variant of TIAC



system operation is very reasonable for applying the energy saving technologies, for instance, based on the thermal storage with accumulating excessive (not consumed) cooling capacities at lowered current thermal loads on the cooling system to cover the peak loads.

**Author Contributions:** Conceptualization, A.R. (40%), M.R. (30%), E.T. (10%), K.K. (10%) and D.M. (10%); methodology, A.R. (30%), E.T. (30%) and M.R. (30%); software, A.R.; validation, A.R. (30%) and M.R. (30%); formal analysis, A.R. (30%), E.T. (30%), K.K. (30%), D.M. (30%) and M.R.; writing—original draft preparation, A.R. (30%), E.T. (30%) and M.R. (30%); writing—review and editing, D.M. (50%) and K.K. (50%). All authors have read and agreed to the published version of the manuscript.

**Funding:** This research received no external funding.

**Conflicts of Interest:** The authors declare no conflict of interest.

## Nomenclature

AC	air cooler
AC <sub>HT</sub>	high-temperature air cooler
AC <sub>LT</sub>	low-temperature air cooler
ACh	absorption lithium-bromide chiller
AECh	absorption-ejector chiller
CAECh	cascade absorption-ejector chiller
CDH	cooling degree hour; $CDH = \Delta t \cdot \tau$
COP	coefficient of performance
ECh	ejector chiller
GT	gas turbine
O	optimal point for maximum rate of annual fuel reduction increment
R	rational point for close to maximum annual fuel reduction
SAECh	stage absorption-ejector chiller
SCAECh	stage-cascade absorption-ejector chiller
TIAC	turbine intake air cooling

## Symbols

$B$	total mass fuel consumption decrease, $B = CDH (\Delta b_e / \Delta t) \cdot P_e$ .
$b_e$	specific fuel consumption
$c_a$	specific heat of humid air
CDH	$CDH = \Delta t \cdot \tau$
$d_{amb}$	ambient air absolute humidity
$G_a$	air mass flow rate
$P_e$	power output
$Q_0$	total cooling capacity, heat flow rate
$q_0$	specific cooling capacity—per unit air mass flow rate
$t$	temperature
$t_{amb}$	ambient air temperature
$t_{a2}$	outlet air temperature
$t_0$	refrigerant boiling temperature
$\xi$	specific heat ratio of the total heat (latent and sensible) rejected from air to its sensible heat
$\tau$	time interval
$\varphi_{amb}$	ambient air relative humidity
$\Delta b_e$	specific fuel consumption decrease
$\Delta t$	air temperature decrease
$\sum B_{7,10,15}$	annual total fuel reduction due to cooling turbine intake air to temperatures 7, 10, 15 °C
$\sum b_{7,10,15}$	annual specific fuel reduction (per 1 kW turbine power output) due to cooling turbine intake air to temperatures 7, 10, 15 °C

## Subscripts

a	air
amb	ambient
max	maximum
opt	optimal
rat	rational

Appendix A




Figure A1. Flow chart of calculation procedure.

## References

1. Tiwari, A.K.; Hasan, M.M.; Islam, M. Effect of Ambient Temperature on the Performance of a Combined Cycle Power Plant. *Trans. Can. Soc. Mech. Eng.* **2013**, *37*, 1177–1188. [CrossRef]
2. Günnür, Ş.; Mustafa, N.; Hayati, M.; Halit, D.; Mustafa, K.; Mevlüt, K.; Fadıl, K.; Nuran, Y.; Mohammad, R.A.B. The effect of ambient temperature on electric power generation in natural gas combined cycle power plant—A case study. *Energy Rep.* **2018**, *4*, 682–690.
3. Lin, A.; Sun, Y.; Zhang, H.; Lin, X.; Yang, L.; Zheng, Q. Fluctuating characteristics of air-mist mixture flow with conjugate wall-film motion in a compressor of gas turbine. *Appl. Therm. Eng.* **2018**, *142*, 779–792. [CrossRef]
4. ISO 3046-1:2002. *Reciprocating Internal Combustion Engines—Performance—Part 1: Declarations of Power, Fuel and Lubricating Oil Consumptions, and Test Methods—Additional Requirements for Engines for General Use*; ISO: Geneva, Switzerland, 2014. Available online: <https://www.iso.org/standard/28330.html> (accessed on 14 June 2020).
5. Payrhuber, K.; Trapp, C. GE's New Jenbacher Gas Engines with 2-Stage Turbocharging. In Proceedings of the 7 Internationale Energiewirtschaftstagung an der TU Wien IEWT, Wien, Austria, 16–18 February 2011; 14p.
6. Trapp, C.; Laiminger, S.; Chvatal, D.; Wimmer, A.; Schneßl, E.; Pirker, G. Die neue Gasmotoren generation von GE Jenbacher—Mit zweistufiger Aufladung zu höchsten Wirkungsgraden. In Proceedings of the 32nd Internationales Wiener Motorensymposium, Wien, Austria, 5–6 May 2011.
7. Radchenko, A.; Mikielewicz, D.; Forduy, S.; Radchenko, M.; Zubarev, A. Monitoring the Fuel Efficiency of Gas Engine in Integrated Energy System. In Proceedings of the Advances in Intelligent Systems and Computing, Kharkiv, Ukraine, 28–30 November 2019; Volume 1113, pp. 361–370.
8. Farouk, N.; Sheng, L.; Hayat, Q. Effect of Ambient Temperature on the Performance of Gas Turbines Power Plant. *Int. J. Comput. Sci.* **2013**, *10*, 439–442.
9. Baakeem, S.S.; Orfi, J.; Al Ansary, H. Performance of a Typical Simple Gas Turbine Unit under Saudi Weather Conditions. *Int. J. Fluid Mechan. Therm. Sci.* **2015**, *1*, 59–71.
10. De Sa, A.; Al Zubaidy, S. Gas turbine performance at varying ambient temperature. *Appl. Therm. Eng.* **2011**, *31*, 2735–2739. [CrossRef]
11. Shukla, A.K.; Singh, O. Thermodynamic investigation of parameters affecting the execution of steam injected cooled gas turbine based combined cycle power plant with vapor absorption inlet air cooling. *Appl. Therm. Eng.* **2017**, *122*, 380–388. [CrossRef]
12. Al-Ibrahim, A.M.; Varnham, A. A review of inlet air-cooling technologies for enhancing the performance of combustion turbines in Saudi Arabia. *Appl. Therm. Eng.* **2010**, *30*, 1879–1888. [CrossRef]
13. Zhang, T.; Liu, Z.; Hao, H.; Chang, L. Application Research of Intake-Air Cooling Technologies in Gas-Steam Combined Cycle Power Plants in China. *J. Power Energy Eng.* **2014**, *2*, 304–311. [CrossRef]
14. Chaker, M.; Meher-Homji, C.B. Inlet Fogging of Gas Turbine Engines: Climatic Analysis of Gas Turbine Evaporative Cooling Potential of International Locations. *J. Eng. Gas Turbines Power* **2006**, *128*, 815–825. [CrossRef]
15. Saghafifar, M.; Gadalla, M. Analysis of Maisotsenko open gas turbine power cycle with a detailed air saturator model. *Appl. Energy* **2015**, *149*, 338–353. [CrossRef]
16. Dizaji, H.S.; Hu, E.J.; Chen, L.; Pourhedayat, S. Using novel integrated Maisotsenko cooler and absorption chiller for cooling of gas turbine inlet air. *Energy Convers. Manag.* **2019**, *195*, 1067–1078. [CrossRef]
17. Rocha, M.; Andreos, R.; Simões-Moreira, J.R. Performance tests of two small trigeneration pilot plants. *Appl. Therm. Eng.* **2012**, *41*, 84–91. [CrossRef]
18. Freschi, F.; Giacccone, L.; Lazzeroni, P.; Repetto, M. Economic and environmental analysis of a trigeneration system for food-industry: A case study. *Appl. Energy* **2013**, *107*, 157–172. [CrossRef]
19. Marques, R.P.; Hacon, D.; Tessarollo, A.; Parise, J.A.R. Thermodynamic analysis of tri-generation systems taking into account refrigeration, heating and electricity load demands. *Energy Build.* **2010**, *42*, 2323–2330. [CrossRef]
20. Ortiga, J.; Bruno, J.C.; Coronas, A. Operational optimization of a complex trigeneration system connected to a district heating and cooling network. *Appl. Therm. Eng.* **2013**, *50*, 1536–1542. [CrossRef]

21. Dr. Fromme International Consulting. *Cogeneration & Trigeneration—How to Produce Energy Efficiently: A Practical Guide for Experts in Emerging and Developing Economies*, GIZ GmbH, Germany; Dr. Fromme International Consulting: Essen, Germany, 2016; 144p. Available online: <https://www.dfic.de/images/pdf/cogeneration-trigeneration-guide.pdf> (accessed on 14 June 2020).
22. Muszyński, T.; Mikielwicz, D. Comparison of heat transfer characteristics in surface cooling with boiling microjets of water, ethanol and HFE7100. *Appl. Therm. Eng.* **2016**, *93*, 1403–1409. [[CrossRef](#)]
23. Chacartegui, R.; Jiménez-Espadafor, F.; Sánchez, D.; Sánchez, T. Analysis of combustion turbine inlet air cooling systems applied to an operating cogeneration power plant. *Energy Convers. Manag.* **2008**, *49*, 2130–2141. [[CrossRef](#)]
24. Khaliq, A.; Dincer, I.; Sharma, P.B. Development and analysis of industrial waste heat based trigeneration for combined production of power heat and cold. *J. Energy Inst.* **2010**, *83*, 79–85. [[CrossRef](#)]
25. Popli, S.; Rodgers, P.; Eveloy, V. Trigeneration scheme for energy efficiency enhancement in a natural gas processing plant through turbine exhaust gas waste heat utilization. *Appl. Energy* **2012**, *93*, 624–636. [[CrossRef](#)]
26. Popli, S.; Rodgers, P.; Eveloy, V. Gas turbine efficiency enhancement using waste heat powered absorption chillers in the oil and gas industry. *Appl. Therm. Eng.* **2013**, *50*, 918–931. [[CrossRef](#)]
27. Ameri, M.; Hejazi, S. The study of capacity enhancement of the Chababar gas turbine installation using an absorption chiller. *Appl. Therm. Eng.* **2004**, *24*, 59–68. [[CrossRef](#)]
28. Ehyaei, M.A.; Hakimzadeh, S.; Enadi, N.; Ahmadi, P. Exergy, economic and environment (3E) analysis of absorption chiller inlet air cooler used in gas turbine power plants. *Int. J. Energy Res.* **2011**, *36*, 486–498. [[CrossRef](#)]
29. Andi, B.; Venkatesan, J.; Suresh, S.; Mariappan, V. Experimental Analysis of Triple Fluid Vapour Absorption Refrigeration System Driven by Electrical Energy and Engine Waste Heat. *Therm. Sci.* **2019**, *23*, 2995–3001.
30. Elberry, M.; Elsayed, A.; Teamah, M.; Abdel-Rahman, A.; Elsafty, A. Performance improvement of power plants using absorption cooling system. *Alex. Eng. J.* **2018**, *57*, 2679–2686. [[CrossRef](#)]
31. Umberto, L. Adsorber efficiency in adsorption refrigeration. *Renew. Sustain. Energy Rev.* **2013**, *20*, 570–575.
32. Sur, A.; Das, R.; Sah, R. Influence of initial bed temperature on bed performance of an adsorption refrigeration system. *Therm. Sci.* **2018**, *22*, 2583–2595. [[CrossRef](#)]
33. Suamir, I.; Tassou, S. Performance evaluation of integrated trigeneration and CO<sub>2</sub> refrigeration systems. *Appl. Therm. Eng.* **2013**, *50*, 1487–1495. [[CrossRef](#)]
34. Bohdal, T.; Kuczynski, W. Boiling of R404A Refrigeration Medium Under the Conditions of Periodically Generated Disturbances. *Heat Transf. Eng.* **2011**, *32*, 359–368. [[CrossRef](#)]
35. Bohdal, T.; Sikora, M.; Widomska, K.; Radchenko, A.M. Investigation of flow structures during HFE-7100 refrigerant condensation. *Arch. Thermodyn.* **2015**, *36*, 25–34. [[CrossRef](#)]
36. Kuczyński, W.; Charun, H. Experimental investigations into the impact of the void fraction on the condensation characteristics of R134a refrigerant in minichannels under conditions of periodic instability. *Arch. Thermodyn.* **2011**, *32*, 21–37. [[CrossRef](#)]
37. Kuczyski, W.; Charun, H.; Bohdal, T.; Kuczynski, W. Influence of hydrodynamic instability on the heat transfer coefficient during condensation of R134a and R404A refrigerants in pipe mini-channels. *Int. J. Heat Mass Transf.* **2012**, *55*, 1083–1094. [[CrossRef](#)]
38. Radchenko, M.; Mikielwicz, D.; Tkachenko, V.; Klugmann, M.; Andreev, A. Enhancement of the Operation Efficiency of the Transport Air Conditioning System. In Proceedings of the Lecture Notes in Mechanical Engineering, Kharkiv, Ukraine, 9–12 June 2020; pp. 332–342.
39. Trushliakov, E.; Radchenko, M.; Bohdal, T.; Radchenko, R.; Kantor, S. An Innovative Air Conditioning System for Changeable Heat Loads. In Proceedings of the Lecture Notes in Mechanical Engineering, Odessa, Ukraine, 10–13 September 2019; pp. 616–625.
40. Mikielwicz, D.; Wajs, J. Performance of the very high-temperature heat pump with low GWP working fluids. *Energy* **2020**, *182*, 460–470. [[CrossRef](#)]
41. Forduy, S.; Radchenko, A.M.; Kuczynski, W.; Zubarev, A.; Konovalov, D. Enhancing the Gas Engines Fuel Efficiency in Integrated Energy System by Chilling Cyclic Air. In Proceedings of the Lecture Notes in Mechanical Engineering, Kharkiv, Ukraine, 9–12 June 2020; pp. 500–509.

42. Butrymowicz, D.; Gagan, J.; Śmierciew, K.; Łukaszuk, M.; Dudar, A.; Pawluczuk, A.; Łapiński, A.; Kuryłowicz, A. Investigations of prototype ejection refrigeration system driven by low grade heat. *E3S Web Conf.* **2018**, *70*, 03002. [[CrossRef](#)]
43. Elbel, S.; Lawrence, N. Review of recent developments in advanced ejector technology. *Int. J. Refrig.* **2016**, *62*, 1–18. [[CrossRef](#)]
44. Lawrence, N.; Elbel, S. Experimental investigation of a two-phase ejector cycle suitable for use with low-pressure refrigerants R134a and R1234yf. *Int. J. Refrig.* **2014**, *38*, 310–322. [[CrossRef](#)]
45. Radchenko, R.; Kornienko, V.; Pyrysunko, M.; Bogdanov, M.; Andreev, A. Enhancing the Efficiency of Marine Diesel Engine by Deep Waste Heat Recovery on the Base of Its Simulation Along the Route Line. In Proceedings of the Advances in Intelligent Systems and Computing, Kharkiv, Ukraine, 28–30 November 2019; Volume 1113, pp. 337–350.
46. Kornienko, V.; Radchenko, M.; Radchenko, R.; Konovalov, D.; Andreev, A.; Pyrysunko, M. Improving the efficiency of heat recovery circuits of cogeneration plants with combustion of water-fuel emulsions. *Therm. Sci.* **2020**, 154. [[CrossRef](#)]
47. Konovalov, D.; Trushliakov, E.; Radchenko, M.; Kobalava, H.; Maksymov, V. Research of the Aerothermopressor Cooling System of Charge Air of a Marine Internal Combustion Engine Under Variable Climatic Conditions of Operation. In Proceedings of the Grabchenko's International Conference on Advanced Manufacturing Processes, Odessa, Ukraine, 10–13 September 2019; pp. 520–529.
48. Konovalov, D.; Kobalava, H.; Maksymov, V.; Radchenko, R.; Avdeev, M. Experimental Research of the Excessive Water Injection Effect on Resistances in the Flow Part of a Low-Flow Aerothermopressor. In Proceedings of the Advances in Design, Simulation and Manufacturing III, Kharkiv, Ukraine, 9–12 June 2020; pp. 292–301.
49. Kornienko, V.; Radchenko, R.; Stachel, A.; Andreev, A.; Pyrysunko, M. Correlations for Pollution on Condensing Surfaces of Exhaust Gas Boilers with Water-Fuel Emulsion Combustion. In Proceedings of the Grabchenko's International Conference on Advanced Manufacturing Processes, Odessa, Ukraine, 10–13 September 2019; pp. 530–539.
50. Kornienko, V.; Radchenko, R.; Konovalov, D.; Andreev, A.; Pyrysunko, M. Characteristics of the Rotary Cup Atomizer Used as Afterburning Installation in Exhaust Gas Boiler Flue. In Proceedings of the Advances in Design, Simulation and Manufacturing III, Kharkiv, Ukraine, 9–12 June 2020; pp. 302–311.
51. Trushliakov, E.; Radchenko, A.; Radchenko, M.; Kantor, S.; Zielikov, O. The Efficiency of Refrigeration Capacity Regulation in the Ambient Air Conditioning Systems. In Proceedings of the Advances in Design, Simulation and Manufacturing III, Kharkiv, Ukraine, 9–12 June 2020; pp. 343–353.
52. Mikielwicz, D.; Kosowski, K.; Tucki, K.; Piwowarski, M.; Stępień, R.; Orynych, O.; Włodarski, W. Gas Turbine Cycle with External Combustion Chamber for Prosumer and Distributed Energy Systems. *Energies* **2019**, *12*, 3501. [[CrossRef](#)]
53. Wajs, J.; Mikielwicz, D.; Jakubowska, B. Performance of the domestic micro ORC equipped with the shell-and-tube condenser with minichannels. *Energy* **2018**, *157*, 853–861. [[CrossRef](#)]
54. Leonzio, G. An innovative trigeneration system using biogas as renewable energy. *Chin. J. Chem. Eng.* **2018**, *26*, 1179–1191. [[CrossRef](#)]
55. Maraver, D.; Sin, A.; Royo, J.; Sebastián, F. Assessment of CCHP systems based on biomass combustion for small-scale applications through a review of the technology and analysis of energy efficiency parameters. *Appl. Energy* **2013**, *102*, 1303–1313. [[CrossRef](#)]
56. Cherednichenko, O.; Havrysh, V.; Shebanin, V.; Kalinichenko, A.; Mentel, G.; Nakonieczny, J. Local Green Power Supply Plants Based on Alcohol Regenerative Gas Turbines: Economic and Environmental Aspects. *Energies* **2020**, *13*, 2156. [[CrossRef](#)]
57. Cherednichenko, O.; Mitienkova, V. Analysis of the Impact of Thermochemical Recuperation of Waste Heat on the Energy Efficiency of Gas Carriers. *J. Mar. Sci. Appl.* **2020**, *19*, 72–82. [[CrossRef](#)]
58. Mikielwicz, D.; Wajs, J.; Andrzejczyk, R.; Klugmann, M. Pressure drop of HFE7000 and HFE7100 during flow condensation in minichannels. *Int. J. Refrig.* **2016**, *68*, 226–241. [[CrossRef](#)]
59. Yang, C.; Yang, Z.; Cai, R. Analytical method for evaluation of gas turbine inlet air cooling in combined cycle power plant. *Appl. Energy* **2009**, *86*, 848–856. [[CrossRef](#)]
60. Mahmoudi, S.; Zare, V.; Ranjbar, F.; Farshi, L.G. Energy and Exergy Analysis of Simple and Regenerative Gas Turbines Inlet Air Cooling Using Absorption Refrigeration. *J. Appl. Sci.* **2009**, *9*, 2399–2407. [[CrossRef](#)]

61. Chaker, M.; Meher-Homji, C.B.; Mee, T.; Nicholson, A. Inlet Fogging of Gas Turbine Engines Detailed Climatic Analysis of Gas Turbine Evaporation Cooling Potential in the USA. *J. Eng. Gas Turbines Power* **2002**, *125*, 300–309. [[CrossRef](#)]
62. Coskun, C.; Demiral, D.; Ertürk, M.; Oktay, Z. Modified Degree-Hour Calculation Method. Available online: <http://www.intechopen.com/books/solar-power/modified-degree-hour-calculation-method> (accessed on 10 June 2020).
63. Forsyth, J.L. Gas turbine inlet air chilling for LNG. In Proceedings of the IGT International Liquefied Natural Gas Conference, Houston, TX, USA, 6–19 April 2013; Volume 3, pp. 1763–1778. Available online: <https://www.scopus.com/record/display.uri?eid=2-s2.0-84904725071&origin=inward&txGid=b9d07662f250f4a4511cbfc9c242297a> (accessed on 10 June 2020).
64. Kalhori, S.B.; Rabiei, H.; Mansoori, Z. Mashad trigeneration potential—An opportunity for CO<sub>2</sub> abatement in Iran. *Energy Conv. Manag.* **2012**, *60*, 106–114. [[CrossRef](#)]
65. Canova, A.; Cavallero, C.; Freschi, F. Optimal energy management. *IEEE Ind. Appl. Mag.* **2009**, *15*, 62–65. [[CrossRef](#)]
66. Rodriguez-Aumente, P.A.; Rodriguez-Hidalgo, M.D.C.; Nogueira, J.I.; Lecuona, A.; Venegas, M.D.C. District heating and cooling for business buildings in Madrid. *Appl. Therm. Eng.* **2013**, *50*, 1496–1503. [[CrossRef](#)]
67. Kavvadias, K.; Maroulis, Z. Multi-objective optimization of a trigeneration plant. *Energy Policy* **2010**, *38*, 945–954. [[CrossRef](#)]
68. Lozano, M.A.; Ramos, J.C.; Serra, L.M. Cost optimization of the design of CHCP (combined heat, cooling and power) systems under legal constraints. *Energy* **2010**, *35*, 794–805. [[CrossRef](#)]
69. Radchenko, A.; Radchenko, M.; Trushliakov, E.; Kantor, S.; Tkachenko, V. Statistical Method to Define Rational Heat Loads on Railway Air Conditioning System for Changeable Climatic Conditions. In Proceedings of the 5th International Conference on Systems and Informatics (ICSAI), Nanjing, China, 10–12 November 2018; pp. 1294–1298.
70. Radchenko, M.; Radchenko, R.; Tkachenko, V.; Kantor, S.; Smolyanoy, E. Increasing the Operation Efficiency of Railway Air Conditioning System on the Base of Its Simulation Along the Route Line. In Proceedings of the Advances in Intelligent Systems and Computing, Kharkiv, Ukraine, 28–30 November 2019; Volume 1113, pp. 461–467.
71. Radchenko, A.; Bohdal, Ł.; Zongming, Y.; Portnoi, B.; Tkachenko, V. Rational Designing of Gas Turbine Inlet Air Cooling System. In Proceedings of the Grabchenko’s International Conference on Advanced Manufacturing Processes, Odessa, Ukraine, 10–13 September 2019; pp. 591–599.
72. Reynolds, O., IV. On the dynamical theory of incompressible viscous fluids and the determination of the criterion. *Philos. Trans. R. Soc. A Math. Phys. Eng. Sci.* **1895**, *186*, 123–164. [[CrossRef](#)]
73. Hewitt, G.; Govan, A. Phenomenological modelling of non-equilibrium flows with phase change. *Int. J. Heat Mass Transf.* **1990**, *33*, 229–242. [[CrossRef](#)]
74. Available online: <http://www.meteomanz.com> (accessed on 12 June 2020).
75. GPF Software. Available online: <https://www.guentner.eu/know-how/product-calculator-gpc/gpc-software/> (accessed on 10 June 2020).

**Publisher’s Note:** MDPI stays neutral with regard to jurisdictional claims in published maps and institutional affiliations.



© 2020 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<http://creativecommons.org/licenses/by/4.0/>).

